

MSDP

Municipal Services Delivery Program
P & D Department, Government of Sindh



No:PS/MSDP/Jcbd/WS-2/2014 May 27, 2014

MUHAMMAD NAEEM WAHEED

PROCUREMENT SPECIALIST

ADDENDUM/CORRIGENDUM-1

Contract Package WS-04:

Water Distribution Network Zone 1 & 2

VOLUME-I (B) BILL NO-A: WATER DISTRIBUTION NETWORK

Please refer to bidding documents issued in respect of Contract Package WS-04 (Water Distribution Network Zone 1 & 2) and note the following addendum/corrigendum:

The original text of BOQ Item A/5 is deleted and is replaced with the following text and shall now be read
as under:

"Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification, (Test certificate from manufacturer) and as per direction of Engineer."

All the remaining items including sizes, unit and quantities shall remain the same.

A revised BOQ Page No-7 is attached with this Addendum-1. Please replace the existing Page No-7 with the revised BOQ Page No-7.

USAID

SINDH-MSDP

- In Drawing No. MSPJ-WS04-501, working pressure shall be read as 10 bar instead of 16 bar in the last line of the first table.
- You are requested to please note the above changes, replace the pages, price them accordingly and attach with the BOQ.
- Inconvenience caused is very much regretted.

Enclosure: as above

To:

- Secretary (Planning) Planning & Development Department, Government of Sindh
- 2. Managing Director, SPPRA, Karachi
- 3. Mr Ghufran Shafi, MSDP Engineering Specialist-USAID/Pakistan, Karachi
- 4. The Executive Engineer, Public Health Engineering Division, Jacobabad
- Chief of the Party, AAA+TCI
- 6. M/s. Muhammad Idrees, Karkhana Shaikh Salahuddin Chowk Shahdra, Bahawalpur.
- 7. M/s. Matracon Pakistan (Pvt). Ltd, House No.276-B, Main Double Road, F-10/4, Islamabad
- 8. M/s. Samad Khan Babar & Co, H.# C-225, Block-A, North Nazimabad, Karachi
- 9. M/s. Muhammad Ayoub & Brothers, Civil Engineering Contractors, 825/C, Block-2, PECHS
- 10. M/s. Shaikh Baz Khan & Brothers, B-40, G.Floor, Block-T, North Nazimabad, Karachi
- M/s. Crescent Construction Co & KSB Engineers & Contractors, SA-23, 2nd Floor, Shahnaz Arcade, Shaheed-e-Millat Road, Karachi.
- 12. M/s. Muhammad Iqbal Shaikh & Co, F/1248, Aziz Nest near Ibrat Press, Gari Khata, Hyderabad
- 13. M/s. Khan Muhammad Khan & Co., House No.2, Street No.1, Khayaban-e-Sehar, DHA PH-VI, Karachi
- *14. M/s. Al-Mansoor (Pvt) Ltd & M/s. Alam Engineering (JV), A-7, 3rd Floor Islamic Plaza, Block-13/B-2, Gulshan-e-Iqbal, Karachi
- 15. M/s. Salman Enterprises, Bunglow No:141, Block-B, Unit-3, Latifabad, Hyderabad
- 16. M/s. ZLMS-AHCS (JV), Office No.3469/4, Barage Road, Teer Chowk, Sukkur

20920

MUNICIPAL SERVICES PROGRAM (MSP) JACOBABAD

BILL OF QUANTITIES

CIVIL WORKS

BILL NO - A :- WATER DISTRIBUTION NETWORK

Addendum # 1


Revised B.O.O Page No - 7, (WS-04)

S NO	Item Description	Unit	Quantity		Amount	
				In figure	In words	(Rs)
	(vii) 400mm Outer Dia	No	2			
A/4	Providing and Fixing Pressure gauges of approved quality on 500mm pipe with 1.5 meter long 20 mm G.I pipe and clamp to suit the diameter of pipe, with welded socket including nuts bolts etc complete as per specifications and direction of Engineer	No	2			
A/S	Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification. (Test certificate from manufacturer) and as per direction of Engineer.					
	(i) 110mm Outer Dia	No	50			
	(ii) 160mm Outer Dia	No	4			
	(iii) 200mm Outer Dia	No	8			
	(iv) 250mm Outer Dia	No	4			
	(v) 315mm Outer Dia	No	8			
	(vi) 355mm Outer Dia	No	2			
	(vii) 400mm Outer Dia	No	2			
	CARRIED TO COLLECTION	-	1			1

SIGNATURE OF CONTRACTOR

SEAL





MSDP

Municipal Services Delivery Program P & D Department, Government of Sindh



No:PS/MSDP/Jcbd/WS-2/2014 May 27, 2014

ADDENDUM/CORRIGENDUM-2

Contract Package WS-06:

Water Distribution Network Zone 5 & 6

VOLUME-I (B): BILL NO-A: WATER DISTRIBUTION NETWORK

Please refer to bidding documents issued in respect of Contract Package WS-06 (Water Distribution Network Zone 5 & 6) and note the following addendum/corrigendum:

1. The original text of BOQ Item A/5 is deleted and is replaced with the following text and shall now be read as under:

"Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification, (Test certificate from manufacturer) and as per direction of Engineer."

All the remaining items including sizes, unit and quantities shall remain the same.

A revised BOQ Page No-7 is attached with this Addendum-1. Please replace the existing Page No-7 with the revised BOQ Page No-7.

USAID

2. In Drawing No. MSPJ-WS06-501, working pressure shall be read as 10 bar instead of 16 bar in the last line of the first table2.

You are requested to please note the above changes, replace the pages, price them accordingly and attach with 2. the BOQ.

3. Inconvenience caused is very much regretted.

Enclosure: as above

To:

Secretary (Planning) Planning & Development Department, Government of Sindh

Managing Director, SPPRA, Karachi

- Mr. Ghufran Shafi, MSDP Engineering Specialist-USAID/Pakistan, Karachi
- The Executive Engineer, Public Health Engineering Division, Jacobabad

Chief of the Party, AAA+TCI

- M/s. Muhammad Idrees, Karkhana Shaikh Salahuddin Chowk Shahdra, Bahawalpur.
- M/s. Matracon Pakistan (Pvt). Ltd, House No.276-B, Main Double Road, F-10/4, Islamabad
- M/s. Samad Khan Babar & Co, H.# C-225, Block-A, North Nazimabad, Karachi
- M/s. Muhammad Ayoub & Brothers, Civil Engineering Contractors, 825/C, Block-2, PECHS
- 10. M/s. Shaikh Baz Khan & Brothers, B-40, G.Floor, Block-T, North Nazimabad, Karachi
- 11. M/s. Crescent Construction Co & KSB Engineers & Contractors, SA-23, 2nd Floor, Shahnaz Arcade, Shaheede-Millat Road, Karachi.
- 12. M/s. Muhammad Iqbal Shaikh & Co, F/1248, Aziz Nest near Ibrat Press, Gari Khata, Hyderabad
- M/s. Khan Muhammad Khan & Co., House No.2, Street No.1, Khayaban-e-Sehar, DHA PH-VI, Karachi
- M/s. Al-Mansoor (Pvt) Ltd & M/s. Alam Engineering (JV), A-7, 3rd Floor Islamic Plaza, Block-13/B-2, Gulshan-e-Iqbal, Karachi
- 15. M/s. Salman Enterprises, Bunglow No:141, Block-B, Unit-3, Latifabad, Hyderabad
- M/s. ZLMS-AHCS (JV), Office No.3469/4, Barage Road, Teer Chowk, Sukkur

MUHAMMAD NAEEM WAHEED SINDH-MSDP PROCUREMENT SPECIALIST

C 0

MUNICIPAL SERVICES PROGRAM (MSP) JACOBABAD

BILL OF QUANTITIES

CIVIL WORKS

BILL NO - A :- WATER DISTRIBUTION NETWORK

Addendum # 2

Revised B.O.O.Page No - 7, (WS-06)

The same of the sa	Unit	Quantity	Rate		
Item Description			In figure	In words	(Rs.)
Providing and Fixing Pressure gauges of approved quality on 600mm pipe with 1.5 meter long 20 mm G.I pipe and clamp to suit the diameter of pipe, with welded socket including nuts bolts etc complete as per specifications and direction of Engineer.	No	2			
Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification, (Test certificate from manufacturer) and as per direction of Engineer.					
(i) 110mm Outer Dia	No	24			
(ii) 160mm Outer Dia	No	15			
(iii) 200mm Outer Dia	No	7			
(iv) 250mm Outer Dia	No	3			
(v) 315mm Outer Dia	No	3			
(vi) 355mm Outer Dia	No	1			
(vii) 400mm Outer Dia	No	2			1,4
2 1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	approved quality on 600mm pipe with 1.5 meter long 20 mm G.I pipe and clamp to suit the diameter of pipe, with welded socket including nuts bolts etc complete as per specifications and direction of Engineer. Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification. (Test certificate from manufacturer) and as per direction of Engineer. (ii) 110mm Outer Dia (iii) 200mm Outer Dia (iv) 250mm Outer Dia (v) 315mm Outer Dia (vi) 355mm Outer Dia	approved quality on 600mm pipe with 1.5 meter long 20 mm G.I pipe and clamp to suit the diameter of pipe, with welded socket including nuts bolts etc complete as per specifications and direction of Engineer. Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification. (Test certificate from manufacturer) and as per direction of Engineer. (ii) 110mm Outer Dia No (iii) 160mm Outer Dia No (iv) 250mm Outer Dia No (v) 315mm Outer Dia No (vi) 355mm Outer Dia No	approved quality on 600mm pipe with 1.5 meter long 20 mm G.I pipe and clamp to suit the diameter of pipe, with welded socket including nuts bolts etc complete as per specifications and direction of Engineer. Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification. (Test certificate from manufacturer) and as per direction of Engineer. (ii) 110mm Outer Dia No 15 (iii) 200mm Outer Dia No 3 (iv) 250mm Outer Dia No 3 (v) 315mm Outer Dia No 1	Providing and Fixing Pressure gauges of approved quality on 600mm pipe with 1.5 meter long 20 mm G.I pipe and clamp to suit the diameter of pipe, with welded socket including nuts botts etc comptete as per specifications and direction of Engineer. Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification. (Test certificate from manufacturer) and as per direction of Engineer. (ii) 110mm Outer Dia No 15 (iii) 160mm Outer Dia No 3 (iv) 250mm Outer Dia No 3 (v) 315mm Outer Dia No 1	Providing and Fixing Pressure gauges of approved quality on 600mm pipe with 1.5 meter long 20 mm G.I pipe and clamp to suit the diameter of pipe, with welded socket including nuts bolts etc complete as per specifications and direction of Engineer. Providing and Fixing Gate Valves PN-10 of required dia of imported approved quality including rubber packing, galvanized nuts and bolts; etc complete as per drawings specification. (Test certificate from manufacturer) and as per direction of Engineer. (ii) 110mm Outer Dia No 15 (iii) 200mm Outer Dia No 3 (v) 315mm Outer Dia No 1

SIGNATURE OF CONTRACTOR

SEAL

