



**2ND MEETING OF PROCUREMENT COMMITTEE OF LIVESTOCK & FISHERIES
DEPARTMENT TO BE HELD ON 07.10.2015 FOR PURCHASE OF GENERATOR
FOR SINDH POULTRY VACCINE CENTRE, KARACHI**

ATTENDANCE SHEET

S. #	NAME	Contact Tel & Email	SIGNATURE
01.	DR. ABDULLAH MEWATI, Director General (Extension & Research), Livestock Department, Government of Sindh, Hyderabad		In Chair
02.	DR. NAZEER HUSSAIN KALHORO, Executive Director, Sindh Poultry Vaccine Centre, Korangi, Karachi	03114605474	
03.	MR. MUSHTAQ ALI UJJAN Industries Department Government of Sindh, Karachi	03007069794	

MINUTES OF 2ND MEETING OF THE PROCUREMENT COMMITTEE OF LIVESTOCK & FISHERIES DEPARTMENT HELD ON 07.10.2015 AT COMMITTEE ROOM OF DIRECTOR, SINDH POULTRY VACCINE CENTRE, KORANGI, KARACHI TO DISCUSS AND SCRUTINIZE THE TECHNICAL BIDS FOR PURCHASE OF GENERATOR FOR SINDH POULTRY VACCINE CENTRE, KARACHI

The meeting was started with recitation from Holy Quran.

The comparative statement / technical evaluation was prepared for various items and placed before the committee, the chairman briefed the house about fair response of the tenderers. The Procurement Committee discussed each item separately, scrutinized the bids technically and decided to open the financial bids of only successful bidders in presence of the interested bidders / their authorized representatives in its next meeting. Unsuccessful bidders will be returned their financial unopened. The decisions / recommendation of the Procurement Committee are as under:





SINDH POULTRY VACCINE CENTRE, LIVESTOCK & FISHERIES DEPARTMENT,
GOVERNMENT OF SINDH, KARACHI
COMPARATIVE STATEMENT FOR TECHNICAL BID EVALUATION




**PLANT
&
MACHINERY**

Handwritten signature



**SINDH POULTRY VACCINE CENTRE, LIVESTOCK & FISHERIES DEPARTMENT,
GOVERNMENT OF SINDH, KARACHI
COMPARATIVE STATEMENT FOR TECHNICAL BID EVALUATION**



PLANT & MACHINERY

S.#	Name of Firms	Pay order	Technical Detail	Certificates GST, NTN	Certificate others
01.	M/S S.M. Jaffer & Co	✓	✓	✓	✓
02.	M/S MIA Energy (Pvt.) Ltd	✓	✓	✓	✓
03.	M/S Pak Traders	✓	✓	✓	✓
04.	M/S The Systems	✓	✓	✓	✓
05.	M/s Shahab & Sons	✓	✓	✓	✓
06.	M/s Orient Traders	✓	✓	✓	✓
07.	M/s M. Ahmed Trading	✓	✓	✓	✓
08.	M/s Khair Enterprises	✓	✓	✓	✓
09.	M/s Dawood Hassan Enterprises	✓	✓	✓	✓

Remarks:

Nine (09) firms M/S S.M. Jaffer & Co, M/S MIA Energy (Pvt.) Ltd, M/S Pak Traders, M/S The Systems, M/s Shahab & Sons, M/s Orient Traders, M/s M. Ahmed Trading, M/s Khair Enterprises and M/s Dawood Hassan Enterprises participated in Plant & Machinery Tender. Only three firms i.e. M/s Orient Traders, M/s Khair Enterprises and M/s Dawood Hassan Enterprises provided the technical details according to tender requirements. Therefore, financial bid of only these three bidders will be open for final evaluation.



**SINDH POULTRY VACCINE CENTRE, LIVESTOCK & FISHERIES DEPARTMENT,
GOVERNMENT OF SINDH, KARACHI
COMPARATIVE STATEMENT FOR TECHNICAL BID EVALUATION**




COMPARATIVE : PLANT & MACHINERY

Item No. 1 Item Name : Generator (325-400 KVA)									
325 to 400 KVA Generator Set Frequency 50 Hz Speed 1500 RPM Voltage 380 to 415 Volts Emissions/Fuel Strategy: Low Fuel Consumption, Diesel Engine 4-Stroke Water-Cooled Diesel Compression Ratio 16.3:1 Aspiration Air to Air Aftercooled Displacement 12.5 L Stroke 157.0 mm standard equipment Disposable Air filter Service indicator Radiator package mounted Coolant level sight gauge Low coolant level sensor Coolant drain line with valve, Fan and belt guards Extended Life Coolant Dry exhaust manifold Stainless steel flex fittings Exhaust flange outlet Integral narrow single wall fuel tank base Primary fuel filter with integral water separator Secondary fuel filters Fuel priming pump Engine fuel transfer pump Fuel cooler integral with cooling system Flexible fuel lines Class H insulation Self excited (SE) Class H temperature rise IP23 protection R450 voltage regulator with single phase sensing and load adjustment module Power Center houses EMCP controller and power/control terminations (rear mounted) Circuit breaker, IEC compliant, 3-4 pole (100% Rated) Segregated low voltage wiring termination panel Bottom cable entry Integral Narrow 8hr tank base Linear vibration isolation 24 volt starting motor 24 volt, 45 amp charging alternator Batteries with rack and cables Flywheel housing Low coolant temperature alarm Elbows and flange kits Fuel level switch Manual fuel transfer pump Three phase sensing Oil temperature sensor Battery disconnect switch Battery charger - 5 amp Sound attenuated protective enclosure with integral lifting frame with residential muffler High Ambient enclosure with integral lifting frame									
S.M. Jaffer & Co	MIA Energy (Pvt.) Ltd	Pak Traders	The Systems	Shahab & Sons	Orient Traders	M. Ahmed Trading	Khair Enterprises	Dawood Hassan Enterprises	
1	2	3	4	5	6	7	8	9	
Make FG Wilson Model: P400-1 Output prime rating 350KVA Output standby rating 400KVA	Khonaysser KVP380 Genset Orgion Labanon Prime rating 352 KVA Standby rating 387 KVA Engine Volvo Penta TAD1342GE Sweden	MAN Prime serv Powere diesel generator 400 KVA prime rating MAN German diesel engine Model ID2676 LE221 Mecc Alte (UK) Alternator	Cummins Diesel generator 325 KVA Model: NTA855-G1B sound proof canopy	Grupel Engine Perkins (UK) Model 2206A- E13TAG2 Standby power 405 KVA Prime power 356 KVA	CAT Model C-13 Standby 320 eKW 400KVA 50 Hz 1500 rpm 400 volts Low fuel consumption ACERT Technology 4 stroke diesel engine	Perkins Model 1606A- E93TAG5 300KVA prime power/ 330 KVA stanby Power	CAT Model C-13 Standby 320 eKW 400KVA 50 Hz 1500 rpm 400 volts Low fuel consumption ACERT Technology 4 stroke diesel engine	CAT Model C-13 Standby 320 eKW 400KVA 50 Hz 1500 rpm 400 volts Low fuel consumption ACERT Technology 4 stroke diesel engine	

M. Jaffer



**SINDH POULTRY VACCINE CENTRE, LIVESTOCK & FISHERIES DEPARTMENT,
GOVERNMENT OF SINDH, KARACHI
COMPARATIVE STATEMENT FOR TECHNICAL BID EVALUATION**



S.M. Jaffer & Co	MIA Energy (Pvt.) Ltd	Pak Traders	The Systems	Shahab & Sons	Orient Traders	M. Ahmed Trading	Khair Enterprises	Dawood Hassan Enterprises
Engine: Perkins UK Model: HCI444E UK 2206A-E13TAG2 Cylinders 6/inline Alternator Make: Leroy Somer Model: LL6114B Voltage 400, 3 phase 50Hz frequency 1500 RPM Power wizerd control panell IP rating 23 Insulation class H Batteries 24 volts	Alternator Stamford HCI444E UK Control Module Deep sea DS-7310 Cylinders 6 in line Supply 3phase 50 Hz Local scope Weather & sound proof canopy ATS panel Manual change over panel Tool kit One set of air, fuel lubricating oil, filters	ECO40-1S Deep Sea control module 400 V, 3 phase Water cooled Base fuel tank sound proof canopy Cylinders 6 in line 4 stroke	Standby output rating 325 KVA 260KW Prime output rating 293 KVA 234KW, 380/220V 3 phase 4 wire, 50Hz 0.8 PF@1500 RPM Alternator Stamford, voltmeter, frequency meter, hours counter, lord output circuit breaker panel	Cycle 4 stroke Frequency 50-60Hz Cylinders 6 in line Available voltage 380-415 Refrigeration system water / antifreeze close circuit Alternator Stamford (UK) Automatic control panel	Class H insulation self excited IP23 protection Compression ratio 16.3:1 Disposable Air filter Service indicator Radiator package Low coolant level sensor Coolant drain line with valve Dry exhaust manifold narrow single wall fuel tank base Primary fuel filter with integral water separator Secondary fuel filters	1500 rpm Cylinders 6 in line 4 stroke 50 Hz	Class H insulation self excited IP23 protection Compression ratio 16.3:1 Disposable Air filter Service indicator Radiator package Low coolant level sensor Coolant drain line with valve Dry exhaust manifold narrow single wall fuel tank base Primary fuel filter with integral water separator Secondary fuel filters	Class H insulation self excited IP23 protection Compression ratio 16.3:1 Disposable Air filter Service indicator Radiator package Low coolant level sensor Coolant drain line with valve Dry exhaust manifold narrow single wall fuel tank base Primary fuel filter with integral water separator Secondary fuel filters



**SINDH POULTRY VACCINE CENTRE, LIVESTOCK & FISHERIES DEPARTMENT,
GOVERNMENT OF SINDH, KARACHI
COMPARATIVE STATEMENT FOR TECHNICAL BID EVALUATION**



S.M. Jaffer & Co	MIA Energy (Pvt.) Ltd	Pak Traders	The Systems	Shahab & Sons	Orient Traders	M. Ahmed Trading	Khair Enterprises	Dawood Hassan Enterprises
					Fuel priming pump Engine fuel transfer pump Fuel cooler integral with cooling system adjustment module Power Center houses EMCP controller and power/control terminations (rear mounted) Circuit breaker Bottom cable entry Integral 45 amp charging alternator Elbows and flange kits Fuel level switch		Fuel priming pump Engine fuel transfer pump Fuel cooler integral with cooling system adjustment module Power Center houses EMCP controller and power/control terminations (rear mounted) Circuit breaker Bottom cable entry Integral 45 amp charging alternator Elbows and flange kits Fuel level switch	Secondary fuel filters Fuel priming pump Engine fuel transfer pump Fuel cooler integral with cooling system adjustment module Power Center houses EMCP controller and power/control terminations (rear mounted) Integral 45 amp charging alternator Elbows and flange kits Fuel level switch

Handwritten signatures and initials:
 [Signature]
 [Initials]



**SINDH POULTRY VACCINE CENTRE, LIVESTOCK & FISHERIES DEPARTMENT,
GOVERNMENT OF SINDH, KARACHI
COMPARATIVE STATEMENT FOR TECHNICAL BID EVALUATION**



S.M. Jaffer & Co	MIA Energy (Pvt.) Ltd	Pak Traders	The Systems	Shahab & Sons	Orient Traders	M. Ahmed Trading	Khair Enterprises	Dawood Hassan Enterprises
					Manual fuel transfer pump Three phase sensing		Manual fuel transfer pump Three phase sensing	Elbows and flange kits Fuel level switch Manual fuel transfer pump Three phase sensing


Technical Evaluation Remarks: Nine (09) firms M/S S.M. Jaffer & Co, M/S MIA Energy (Pvt.) Ltd, M/S Pak Traders, M/S The Systems, M/s Shahab & Sons, M/s Orient Traders, M/s M. Ahmed Trading, M/s Khair Enterprises, M/s Dawood Hassan Enterprises participated in the bid for Item No. 01 (Generator 325-400KVA) only three firms i.e. M/s Orient Traders, M/s Khair Enterprises and M/s Dawood Hassan Enterprises provided the technical details according to tender requirements, therefore, financial bid of only these three bidders will be open for final evaluation.


[Handwritten signatures]




SINDH POULTRY VACCINE CENTRE, LIVESTOCK & FISHERIES DEPARTMENT,
GOVERNMENT OF SINDH, KARACHI
COMPARATIVE STATEMENT FOR TECHNICAL BID EVALUATION

The comparative statement are prepared and signed as under:


MR. MUSHTAQ ALI UJJAIN,
Industries Department,
Government of Sindh (Member)


DR. NAZEER HUSSAIN KALHORO,
Executive Director,
Sindh Poultry Vaccine Centre,
Karachi (Member)


DR. ABDULLAH MEWATI
Director General,
Livestock (Extension/Research),
Sindh Hyderabad (Chairman)