

## BID EVALUATION REPORT

1. Name of Procuring Agency : Health department, Govt. of Sindh.  
2. Tender Reference No : INF/KRY/2377/2017  
3. Tender Description/Name of work/item : Tender for Provision, Installation and Commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
4. Method of Procurement : Single Stage Two Envelope bidding procedure  
5. Tender Published : Daily DAWN and Daily Jang, SPPRA, ID no. 33140  
6. Total Bid documents Sold : 8 nos.  
7. Total Bids Received : 06 no.  
8. Technical Bid Opening date : 19-05-2017  
9. No. of Bid technically qualified : 02 no.  
10. Bid(s) Rejected : 04 no.  
11. Financial Bid Opening date : 02-11-2017  
12. Bid Evaluation Report:

S No	Name of Items	Name of Bidders	Cost offered by the bidders	Ranking in terms of cost
0	1	2	3	4
COMPARATIVE STATEMENT ATTACHED				

The Committee has recommended to award the contract to the successful bidders



Section Officer PM&I, Health Department,  
Government of Sindh (Member)

*Naveed Ahmed Soomro*


SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH



Representative of Accountant General Sindh  
Karachi (Member)

**Accounts Officer**  
**Accountant General Sindh,**  
**Karachi.**

*Tariq Ishaq*



Additional Secretary (PM&I)  
Health Department, Government of Sindh  
(Chairman)

*Dr. Jamsheduddin*

DAWN WEDNESDAY MAY 3, 2017



## HEALTH DEPARTMENT GOVERNMENT OF SINDH **TENDER NOTICE**

Health Department, Government of Sindh, is hereby invites sealed bids on Single Stage Two-Envelope bidding procedure from original manufacturers or their authorized distributor only, who are registered in Income Tax, Sale Tax Department and SRB (Where applicable), for the supply of items mentioned below. A complete set of tender document may be purchased from the office of undersigned and also download from SPPRA official web site [www.spprasindh.gov.pk](http://www.spprasindh.gov.pk) the bids must be delivered to this office according to following schedule, which will be opened publicly in the presence of the bidders or their authorized representative who choose to attend on same date.

S.no	Name of Item	bid security	Tender Fee	Completion Times
1	PURCHASE, INSTALLATION AND COMMISSION OF COLD STORAGES, MACHINERY / EQUIPMENT AND FURNITURE FIXTURE FOR STRENGTHENING OF MORTUARIES	2.5%	RS.2000/-	June 2017

1. **Eligibility:** valid registration with income tax & sales tax authorities, SRB Professional Tax
2. **Method of procurement:** Single Stage-Two envelopes procedure
3. **Bidding/Tender Documents:**
  - i. **Issuance:** Documents will be issued from date of publication upto **19-5-2017** at 12:00 noon, on pay order of tender fees (not refundable) in the name of Secretary Health.
  - ii. **Submission:** Last date will be **19-5-2017** at 1:30 p.m.
  - iii. **Opening:** Tender will be opened on **19-05-2017** at 1:30 p.m.
4. **Terms & Conditions.**
  - a. Under following conditions bid will be rejected
    - i. Conditional and telegraphic bids tenders
    - ii. Bids not accompanied by bid security of required amount and form.
    - iii. Bids received after specified date and time
    - iv. Bids of black listed firms.
  - b. **Bid validity period:** - 90 days
  - c. Procuring Committee reserves the right to accept or reject any or all bids prior to award / acceptance of contract as per relevant provisions of SPP Rules, 2010 (Amended, 2017)
  - d. In case Government declared/announced public holiday on the date of opening of Tender, The Tender Will Be submitted / opened on the next working day at same time.

INF/ENV/237/2017

**Section Officer (PM&I)**  
**Health Department, Government of Sindh**

روزنامہ جنگ کراچی، بدھ 3 مئی 2017ء



## HEALTH DEPARTMENT GOVERNMENT OF SINDH TENDER NOTICE

Health Department, Government of Sindh, is hereby invites sealed bids on Single Stage Two Envelope bidding procedure from original manufactures or their authorized distributor only, who are registered in Income Tax, Sale Tax Department and SRB (Where applicable), for the supply of items mentioned below. A complete set of tender document may be purchased from the office of undersigned and also down load from SPPRA official web site [www.spprasindh.gov.pk](http://www.spprasindh.gov.pk) the bids must be delivered to this office according to following schedule, which will be opened publicly in the presence of the bidders or their authorized representative who choose to attend on same date.

S.no	Name of Item	bid security	Tender Fee	Completion Times
1	PURCHASE, INSTALLATION AND COMMISSION OF COLD STORAGES, MACHINERY / EQUIPMENT AND FURNITURE FIXTURE FOR STRENGTHENING OF MORTUARIES	2.5%	RS.2000/-	June 2017

- 1. Eligibility:** valid registration with Income tax & sales tax authorities, SRB Professional Tax
- 2. Method of procurement:** Single Stage-Two envelopes procedure
- 3. Bidding/Tender Documents:**
  - i. Issuance:** Documents will be issued from date of publication upto **19-5-2017** at 12:00 noon, on pay order of tender fees (not refundable) in the name of Secretary Health.
  - ii. Submission:** Last date will be **19-5-2017** at 1:30 p.m.
  - iii. Opening:** Tender will be opened on **19-05-2017** at 1:30 p.m.
- 4. Terms & Conditions.**
  - a. Under following conditions bid will be rejected**
    - i. Conditional and telegraphic bids tenders
    - ii. Bids not accompanied by bid security of required amount and form.
    - iii. Bids received after specified date and time
    - iv. Bids of black listed firms.
  - b. Bid validity period :- 90 days**
  - c. Procuring Committee reserves the right to accept or reject any or all bids prior to award / acceptance of contract as per relevant provisions of SPP Rules, 2010 (Amended, 2017)**
  - d. In case Government declared/announced public holiday on the date of opening of Tender, The Tender Will Be submit ted / opened on the next working day at same time.**

19/5/2017

**Section Officer (PM&I)**  
**Health Department, Government of Sindh**



# ہیلٹ ڈیپارٹمنٹ حکومت سندھ ٹینڈر نوٹیس

ہیلٹ ڈیپارٹمنٹ حکومت سندھ، ہیلتھ انٹرنز جی فراہم لاء اصل میڈیسیٹھرز یا سندن معاز دستریبیوٹر فقط، جسٹس انٹرنس، سیزل ٹیکس کانسٹیبلز، ایس آر بی (جنس لاکر کٹرن جو گو جی) رجسٹرڈ ٹیل جین کان سنگل اسٹیج نو اینیولپ واک طریقہ کار تی ہن ذریعہ مہربند واک گھرائی ٹو، ٹینڈر کاغذ جو حکم مکمل میت ہیٹ صحیح تکنیک جی ایس مان خرید کرنی سیکھی ٹو ین ایس بی بی آر ای جی سرکاری ویب سائٹ [www.spprasindh.gov.pk](http://www.spprasindh.gov.pk) تان ڈائرن لوڈ کرنی سیکھی ٹو، واک لازمی طرح ہیٹن شیدول مطابق ہن آفیس کی بھین گھرجی، جیٹھی موجودگی جی خواہشمند واک ڈینڈن یا سندن معاز نمائندن جی موجودگی جی ہر ساکشی ڈینٹن سرعامر کولیا ویندا۔

نمبر شمار	انٹرنز جو ناو	واک سیکورٹی	ٹینڈر فی	تکمیل جو مندو
1	Mortuaries واسطی کولڈ اسٹوریج، مشینری/ایکویپمنٹ ۽ فریجس، فکسچر جی	2.5%	2000 روپيا	جن، 2017

1. اہلیت: انٹرن ٹیکس ۽ سیزل ٹیکس اختیارین، SRB پروڈیشنل ٹیکس سان کارگر رجسٹریشن،
2. پروکيورمينٹ جو طریقو: سنگل اسٹیج نو اینیولپ طریقہ کار۔
3. واک/ٹینڈر کاغذ:
  - a. اجراء کاغذ اشاعت جی تاریخ کان 19-05-2017 تی منجھند 12:00 وگی تائین ٹینڈر فی جی بی آر ڈی، سیکریٹری ہیلتھ جی نالی پر (ناقابل واپسی) جی ادالگی تی جاری کیا ویندا۔
  - b. اماتن: آخري تاريخ 19-05-2017 منجھند 1:30 وگی تائین ہوندي۔
  - c. کولن: ٹینڈر تاریخ 19-05-2017 منجھند 1:30 وگی کولیا ویندا۔
4. شرط ۽ ضابطا:
  - (a) ہیٹن شرطن تحت واک رد کیا ویندا؛
  - (b) مشروط ۽ ٹیلیگرافک واک/ٹینڈر۔
  - (c) جن واکن سان گھریل رقم ۽ حالت پر بد سیکورٹی شامل نہ ہوندي۔
  - (d) جائیبل تاریخ ۽ وقت کانپور ہینڈل واک۔
  - (e) بلڈک اسٹیڈ فرمں جا واک۔
  - (f) واک جی کارگر ہٹن جو مندو، 90 ڈینٹن
  - (g) پروکيورمينٹ کمیٹی ایس بی بی آر ای، 2010 (نومبر ٹیل 2017) جی لاجیبل تشریحات موجب کانٹریکٹ جی ڈین/قبول کرن کان اگ کٹن بریا سورون واکن کی مطلوب یا رد کرن جو حق محفوظ رکھی تی۔
  - (h) سرکار پاران ٹینڈر کولن واری تاریخ تی عام موکل جو اعلان کرن جی صورت پر ٹینڈر ورنڈل کمر کار واری ڈینٹن تی ساکشی وقت تی اماتیا کولیا ویندا۔

INF/KR/2377/2017

**سیکشن آفیسر (PM&I)**  
**ہیلٹ ڈیپارٹمنٹ، حکومت سندھ**

www.jang.com.pk

پاکستان کے ہر روز نامہ روزنامہ

ABC  
CERTIFIED

باقاعدہ تصدیق شدہ شائع

THE DAILY JANG KARACHI

روزنامہ  
جمگہ سہ ماہی  
بانی میر ظلیل الرحمن

FRIDAY JUNE 23, 2017

جلد 174 جمعہ 27 رمضان المبارک 1438ھ 23 جون 2017

محکمہ صحت ..... حکومت سندھ

فون نمبر: 021-99222568 فیکس نمبر: 021-99222837

نمبر: HD(P&E)/3-2(420)/2017 مورخہ: 14-06-2017



تصدیق شدہ

بابت: این آئی ٹی نمبر INF/KRY-2377/2017

مورخہ: 03-05-2017

نوسٹ ملی ٹینڈر ج 03-05-2017 کو برائے خریداری، تحصیل اور کیمپنگ کولڈ اسٹوریج، مشینری، ایکسپنس اور فرنیچر فیکٹری کے کیمپوں میں مردہ خاتون کی پائیداری کے حوالے سے شائع ہوا تھا جس میں پبلک ٹینڈرنگ اور منڈگان کو مطلع کیا جاتا ہے۔  
جنگر وینڈر میں مندرجہ شدہ تھیلیم کی کمی ہے۔  
"NIT میں تھیلیم جون 2017 اور ج سے اب تھیلیم نومبر 2017" پر بھی جائے۔  
دیگر شرائط وضو ایڈ پوسٹور ج تم ہیں جیسا کہ سابقہ NIT میں شائع ہوئی تھیں اور SPPRA کی ویب سائٹ پر جاری کی گئی ہیں۔

سیکشن آفیسر (PM&I)

محکمہ صحت، حکومت سندھ

بہر وقت گروئی بکنگ آف ہے

(INF/KRY-3174/17)

SAY NO TO  
CORRUPTION

0398



ABC Certified The Largest Circulated Sindhi Daily of Pakistan

هڪ ئي وقت ڪراچي، حيدرآباد ۽ سکر مان شايع ٿيندڙ پهرين سنڌي اخبار

DAILY KAWISH روزانه

Hyderabad Daily Kawish

Thursday 22 June, 2017

(جلد 27) خميس 22 جون 2017 ۽ بمطابق 26 رمضان المبارڪ 1438ھ (شمارو 320) قيمت 15 روپيا

هيلٽ ڊپارٽمينٽ  
گورنمينٽ آف سنڌ

فون نمبر: 021-99222568 ڊيڪي نمبر: 021-99222837

No.HD(P&E)/3-2(420)/2017 Dated: 14-06-2017

**تصحيح**

مضمون: اين آئي ٽي نمبر انفارميشن/ ڪراچي/2017/2377  
تاريخ 03-05-2017

اسپتالن ۾ هوز چريز جي اسٽريٽنگ لاءِ ڪولڊ اسٽوريجز، مشينري/ ايڪيوپمينٽ ۽ فرنيچر فڪسچر جي خريداري، تنصيب ۽ چالو ڪرڻ لاءِ 2017-03-05 تي شايع ٿيل ٽينڊر نوٽيس بابت واڪ ڏيندڙن جي اطلاع لاءِ پترو ٿو ڪجي ته مضمون ۾ ڄاڻايل ٽينڊر ۾ هيٺين تبديلي ڪئي وئي آهي:

”اين آئي ٽي ۾ تڪميل جو وقت جون 2017 ڄاڻايل آهي. هاڻ تڪميل جو وقت نومبر 2017 ڪري پڙهيو وڃي.“

ٻيا شرط ۽ ضابطا ساڳيا رهندا. جيئن اڳوڻي شايع ٿيل اين آئي ٽي ۾ ڏنل ۽ SPPRA ويب سائيت تي رکيل آهن.

سيڪشن آفيسر (PM&A)  
هيلٽ ڊپارٽمينٽ، حڪومت سنڌ

IN/KRY.No.3174/2017

**SAY NO TO CORRUPTION**  
اسان دهشتگردي جي خلاف متحد آهيون

SENTELL

سنڌ و تعليم جي بھترين لاءِ علمي ۽ پھنھو پھار لکي 8 3 9 8 تي لس لس ڪريون

Sindh Public Procurement Authority

33140HealthDeptKh050517 (2).zip - WinRAR [evaluation copy]

File Commands Tools Favorites Options Help

Add Extract To Test View Delete Find Wizard Info VirusScan Comment SFX

33140HealthDeptKh050517 (2).zip - ZIP archive, unpacked size 861,574 bytes

Name	Size	Packed	Type	Modified	CRC32
Local Disk					
Bidding Documents Mortuary Facility.docx	59,114	55,639	Microsoft Word D...	4/27/2017 11:0...	9666488
NTI.PDF	802,460	802,231	Adobe Acrobat Do...	5/8/2017 1:51 ...	64430228

Total 861,574 bytes in 2 files

South Karachi	Karachi Water and Sewerage Board KWSB	2017-05-05 00:00:00	2017-05-25 23:59:59	■
Karachi	Government of Sindh Health Department	2017-05-05 00:00:00	2017-05-19 23:59:59	■
Sukkur	Executive Engineer Education Works Division W & S Dept.	2017-05-05 00:00:00	2017-05-23 23:59:59	■
Sukkur	Executive Engineer Education Works Division W & S Dept.	2017-05-05 00:00:00	2017-05-23 23:59:59	■
Tando Allahyar	Executive Engineer Education Works Division W & S Dept.	2017-05-05 00:00:00	2017-05-23 23:59:59	■

Showing records 1901—1950 of 35072

9:40 PM 11/2/2017

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**MINUTES OF MEETING FOR TECHNICAL BID OPENING**

List of Participant attached

Purchase Committee meeting was held on May 19<sup>th</sup>, 2017 for the opening of technical bids "Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh", at PM&I Wing, Health Department, Government of Sindh, 3rd Floor, Tuglaq House, Sindh Secretariat Building No. 2, Kamal Atta-Turk Road, Karachi.

Meeting was started with the recitation of Holy Quran. Chairman informed the members that tender was invited as per SSPRA Rule 46 (2) amended 2013, Single stage- two envelop procedure, Notice inviting tender (N.I.T) HD(P&E)3-2 (420)/2017 published with reference ID no INF/KRY/2377/2017 in Newspapers: - Dawn, Jang etc & hoisted on the website of SPPRA under SPPRA id no. 33140.

Committee was informed that eight (8) bid documents were purchased by the following interested firms /vendors:


1. M/s. T.K Medical Instruments Co.
2. M/s. Universal Enterprises
3. M/s. Karachi Medial Company
4. M/s. Shohby Traders
5. M/s. BIOS
6. M/s. Sippex Hospitals Supplies
7. M/s. Maha Trading
8. M/s. Medline Technologies

Out of eight (8) companies, following six (6) bidders participated in the tender.


1. M/s. T.K Medical Instruments Co.
2. M/s. Universal Enterprises
3. M/s. Karachi Medial Company
4. M/s. BIOS
5. M/s. Maha Trading
6. M/s. Medline Technologies

Chairman Purchase Committee granted permission for opening of the tender in presence of committee members and representative of bidders. After opening of tender box, technical and financial proposal were separated. Technical Bids were opened, reviewed and singed by committee member. Financial proposals were sealed in the presence of purchase committee and representative of bidders.


The meeting ended with words of thanks.

  
Section Officer PM&I, Health Department,  
Government of Sindh (Member)

SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT.  
GOVERNMENT OF SINDH

  
Representative of Accountant General Sindh  
Karachi (Member)

Accounts Officer  
Accountant General Sindh,  
Karachi.

  
Additional Secretary (PM&I)  
Health Department, Government of Sindh  
(Chairman)






# ATTENDANCE SHEET

MEETING OF PROCUREMENT COMMITTEE SCHEDULED

ON 19-05-2017 AT 01:30 P.M.

For Opening of Technical Evaluation Bids of the Tender of Cold storages,  
Machinery/Equipment and Furniture Fixture for Strengthening of Mortuaries.

<u>S #</u>	<u>Name &amp; Designation</u>	<u>Contact #</u>	<u>Signature</u>
01.	Dr. Jamaluddin Jalalani Additional Secretary (PM&I) Health Department, Govt. of Sindh. Chairman	0336 2003576	
02.	Accountant General Sindh, Karachi. (With the request to send his Representative) Member	TARIQ IRSHAD Accounts Officer Cell # 0312-1222308	 19/5
03.	Mr. Naveed Ahmed Soomro Section Officer (PM&I) Health Department Member / Secretary	0333 2122038	 19/5

# ATTENDANCE SHEET

For Opening of Technical Evaluation Bids of the Tender of Cold storages,  
Machinery/Equipment and Furniture Fixture for Strengthening of Mortuaries.

SCHEDULED ON 19-05-2017 AT 01:30 P.M.

participants			
S #	Name of Representative alongwith name of firm.	Contact #	Signature
1.	MedLine Technologies Pvt Ltd.	0321-8279258 WADAC	
2.	ADIL IQBAL M/BIOS	0345-3380440	
3.	Karachi Medical Company	03009281707 Tareeq	
4.	Kamran Ansari T.K Medical Instruments	0300-8219859 0300-9203161	
5.	Khawaja Raza Wali Maha Trading	0315-4011339. kashif@mahatrading.com.pk 03214370896.	
6.	M. Khalid Universal Enterprises.	0333-2264534 0300-8293603	
7.			
8.			

**Tender' for Provision, Installation and Commissioning of Cold storages, Machinery / Equipment and Furniture Fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**MINUTES OF MEETING FOR FINANCIAL BID OPENING**

**List of Participant attached**

Purchase Committee meeting was held on Nov 2<sup>nd</sup>, 2017 for the opening of financial bids "Tender for Provision, Installation and Commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh", at PM&I Wing, Health Department, Government of Sindh, 3rd Floor, Tuglaq House, Sindh Secretariat Building No. 2, Kamal Atta-Turk Road, Karachi.

Meeting was started with the recitation of Holy Quran. Chairman informed the members that tender was invited as per SSPRA Rule 46 (2) amended 2013, Single stage- two envelop procedure, Notice inviting tender (NIT) HD(P&E)3-2 (420)/2017 published with reference ID no INF/KRY/2377/2017 in Newspapers: - Dawn, Jang & etc and hoisted on the website of SPPRA under SPPRA id no. 33140.


Notice for extension of bid validity up to Nov 2017 was published in newspapers:- Jung, Kawish and etc on June 22<sup>nd</sup> and 23<sup>rd</sup>, 2017. Accordingly Letters to bid validity extension were sent to bidders on Aug 1<sup>st</sup>, 2017. In response to letters, bidders extended their bid validity for 180 days.

Committee was informed that eight (8) bid documents were purchased by the interested firms/vendors. Out of eight (8) companies, following six (6) bidders participated in the tender.


1. M/s. Medline Technologies
2. M/s. BIOS
3. M/s. Maha Trading
4. M/s. T.K Medical Instruments Co.
5. M/s. Karachi Medial Company
6. M/s. Universal Enterprises


Technical Evaluation of bids was carried out by technical committee members held on Oct 27<sup>th</sup>, 2017. Technical offers of two (2) bidders i.e. M/s. Medline Technologies and M/s. BIOS were declared as "Responsive" and remaining four (4) bidders i.e. M/s. Maha Trading, M/s. T.K Medical Instruments Co, M/s. Karachi Medial Company and M/s. Universal Enterprises did not qualify technically due to non-compliance of documents required in Instructions to Bidders /General and Special Conditions of bid and required tender specification.

Financial Bids of M/s. Medline Technologies and M/s. BIOS were opened in the presence of Committee Members and bidder's representatives. M/s. Medline Technologies and M/s. BIOS quoted the prices with both incoterm i.e. CIF and DDP basis. Financial comparative statement is attached.

  
Section Officer PM&I, Health Department,  
Government of Sindh (Member)




SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

  
Additional Secretary (PM&I)  
Health Department, Government of Sindh  
(Chairman)

  
Representative of Accountant General Sindh  
Karachi (Member)  
**Accounts Officer**  
**Accountant General Sindh,**  
**Karachi.**

## ATTENDANCE SHEET

MEETING OF PROCUREMENT COMMITTEE SCHEDULED ON 02 ND NOVEMBER, 2017 AT 3.00 P.M. FOR OPENING OF FINANCIAL BIDS OF THE TENDER OF COLD STORAGE, MACHINERY / EQUIPMENT AND FURNITURE AND FIXTURE FOR STRENGTHENING OF MORTURIES .

SR.NO.	NAME & DESIGNATION CONTACT	SIGNATURE
1.	Dr.Jamaluddin Jalalani, Additional Secretary (PM&I), Health Department, Govt.of Sindh	
2.	Accountant General Sindh ( with a request to send his representative)	 10/11/21/11
3.	Section Officer (PM&I) Health Department	

## ATTENDANCE SHEET

MEETING OF PROCUREMENT COMMITTEE SCHEDULED ON 02 ND NOVEMBER,  
2017 AT 3.00 P.M. FOR OPENING OF FINANCIAL BIDS OF THE TENDER OF COLD  
STORAGE, MACHINERY / EQUIPMENT AND FURNITURE AND FIXTURE FOR  
STRENGTHENING OF MORTUARIES .

SR.NO.	NAME OF THE REPRESENTATIVE ALONGWITH FIRM NAME AND CONTACT NUMBER.	SIGNATURE
1.	Faisal Siddiqui 0302 8237357 Universal Enterprises.	
2.	Khurram Shaha Bios 0333-3831988	
3.	Rana Kashif Rahman Maha Tradings 0315-4011339	
4.	0321-8279258 WAGAS Medline Technologies Pvt Ltd.	
5.	03022401239 Sulter Karachi Medical Co	
6.	Kawran 0300 920901 T.K Medical Instruments Co,	

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**Financial Bid opened on Nov 2<sup>nd</sup> , 2017**

Exchange rate:

US\$. = 105.55

GBP: 140.17

Euro. = 122.99

S No	Name of Items	Name of Firm or Bidder	Cost offered by the Bidder			Ranking in terms of cost
			Unit price in CIF	CIF Price Equivalent PKR	Unit Price in DDP	
0	1	2	3			4
1	Cold Storage Cabinet For Four Body	M/s. BIOS	GBP. 15,194	Rs. 2,129,742.98	Rs. 2,435,000	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	Euro. 23,000	Rs. 2,828,770	Rs. 2,655,000	
2	Hydraulic Trolley	M/s. BIOS	GBP. 2,855	Rs. 400,185	Rs. 425,000	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	Euro. 4,700	Rs. 578,053	Rs. 540,000	
3	Cold Fogging machine	M/s. BIOS	GBP. 738	Rs. 103,445.46	Rs. 109,000	
		M/s. Medline Technologies (Pvt) Ltd.	US\$. 1,050	Rs. 110,827.50	Rs. 6,500	1 <sup>st</sup> lowest
4	Ceiling fan	M/s. BIOS	N/A	N/A	Rs. 5,000	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	N/A	N/A	Rs. 6,500	
5	Exhaust Fan	M/s. BIOS	N/A	N/A	Rs. 2,450	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	N/A	N/A	Rs. 5,500	
6	Stretcher with cover	M/s. BIOS	N/A	N/A	Rs. 48,700	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	N/A	N/A	Rs. 195,000	
7	Stainless steel table	M/s. BIOS	GBP. 735	Rs. 103,024.95	Rs. 119,000	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	Euro. 1,500	Rs. 184,485	Rs. 175,000	
8	Revolving chair	M/s. BIOS	N/A	N/A	Rs. 9,750	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	N/A	N/A	Rs. 14,000	
9	Office table	M/s. BIOS	N/A	N/A	Rs. 20,000	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	N/A	N/A	Rs. 22,000	

SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT.  
GOVERNMENT OF SINDH

ACCOUNTS OFFICER  
Accountant General Sindh,  
Karachi.

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**Financial Bid opened on Nov 2<sup>nd</sup>, 2017**

Exchange rate:           US\$. = 105.55


  GBP: 140.17

  Euro. = 122.99


10	Visiting chair	M/s. BIOS	N/A	N/A	Rs. 1,995	1 <sup>st</sup> lowest
		M/s. Medline Technologies (Pvt) Ltd.	N/A	N/A	Rs.7,250	

**Total as Turnkey project:**


Name of Bidder	Package price on CIF basis (Equivalent to Pak Rupees)	Package price on DDP basis	Ranking in terms of cost
M/s. BIOS	Rs. 91,526,876.84	Rs. 103,156,910.00	1 <sup>st</sup> LOWEST
M/s. Medline Technologies (Pvt) Ltd.	Rs. 126,887,048.50	Rs. 117,418,500.00	2 <sup>nd</sup> Lowest

  
Section Officer PM&I, Health Department,  
Government of Sindh (Member)

SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT.  
GOVERNMENT OF SINDH



  
Representative of Accountant General Sindh,  
Karachi (Member)

Accounts Officer  
Accountant General Sindh,  
Karachi

  
Additional Secretary (PM&I)  
Health Department, Government of Sindh  
(Chairman)

## ATTENDANCE SHEET

Meeting for Technical Evaluation of Bids submitted for Purchase, Installation and Commissioning of Cold Storages, Machinery / Equipment and Furniture & fixture for Strengthening of Mortuaries in Sindh is scheduled to be held on 27-10-2017 at 2:30 p.m. in the office Additional Secretary PM&I, Health Department, 3rd Floor, Tuglaq House, Sindh Secretariat Building No. 02, Kamal Atta Turk Road, Karachi.

S.#	NAME	DESIGNATION	CONTACT	SIGNATURE
1	DR. SYED AMIR RAHN	Deputy Medical Superintendent IMSB TRAUMATIC	0321-242372	
2	PROF SHAHNAZ IMAD KHAN	Professor Pathology BMSI, JPMC	03008247509	
3				
4				
5				



Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017

**TECHNICAL EVALUATION**

- Technical Evaluation of bids was carried out as per instruction to bidder general, special condition of tender and as per criteria mentioned in bid documents.
- Being a complex project and for the smooth installation, commissioning and execution of project, the bids were invited on **TURNKEY BASIS**. Accordingly Manufacturer guarantee was required that **“if authorized distributor fails to carry out any assignment in total or in part the manufacturer will be responsible to carry out the remaining work or complete work.”**

1) **M/s. Karachi Medical Company:**

The Bid submitted by the M/s. Karachi Medical Company declared **NON RESPONSIVE** in Bid evaluation and in Technical Evaluation. Detail is at Annexure I.

2) **M/s. T.K Medical Instrument Co.**

The Bid submitted by the M/s. TK Medical Instrument Co. declared **NON RESPONSIVE** in Bid evaluation and in Technical Evaluation. Detail is at Annexure II.

3) **M/s. BIOS**

The Bid submitted by the M/s. BIOS declared **RESPONSIVE** in Bid evaluation and in Technical Evaluation. Detail is at Annexure III.

4) **M/s. Maha Trading**


The Bid submitted by the M/s. Maha Trading declared **NON RESPONSIVE** in Bid evaluation and in Technical Evaluation. Detail is at Annexure IV.


5) **M/s. Medline Technologies (Pvt.) Ltd.**

The Bid submitted by the M/s. Medline Technologies (Pvt.) Ltd. declared **RESPONSIVE** in Bid evaluation and in Technical Evaluation. Detail is at Annexure V.

6) **M/s. Universal Enterprises**

The Bid submitted by the M/s. Universal Enterprises declared **NON RESPONSIVE** in Bid evaluation and in Technical Evaluation. Detail is at Annexure VI.

  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

  
SECTION OFFICER (PMB&F)  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

  
PROF. SHANTMAZ INDRAD KELMAZ  
M.B.B.S., M. Phil (Path)  
Deptt. of Pathology  
Jinnah Postgraduate Medical Centre,  
Karachi

Tender for provis

and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
ing of Mortuary facility at all Teaching & Major Hospitals in Sindh

For the year 2016-17

Technical Bid opened on May 19, 2017

M/s. Karachi Me


Annexure-I

BID EVALUATION

Bid Evaluation Criteria	M/s. Karachi Medical Company
Bid is submitted as per SPP Rule 2010 (Amended 2013) clause 46(2) single stage two envelope bidding procedures.	Yes
Complete package/Turnkey solution	Yes
Original tender purchase receipt.	Yes
Photocopy of Bid security in shape of pay order.	Yes
Bid Validity : 90 days	Not mentioned in quotation
Compliance of tender terms and conditions, signed and stamped	Yes
Copy of Income Tax Certificate	Yes
Copy of GST Registration Certificate.	Yes
Copy of valid Professional Tax (Excise & Taxation) Certificate	Yes
Submission of Original catalogue of quoted items with technical bid from bidder.	No. Submitted Printed brochure is from Mortuary solution who is the trading division of Stainless steel Manufacturer. Details specs are not provided in order to compare and evaluate the tender specification.
Detail data sheet with essential technical and performance characteristics of the offered item on letter head of bidders.	Not mentioned on the letter head but typed on a plain paper with stamp.
Compliance of quality standard certificate	<b>NO.</b>
Sole Agency certificate:	A copy of authorization letter is submitted from Mortuary solution who is the division of Marston Engineer's Ltd-UK, who are the Manufacture of Stainless Steel products.

  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

  
**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

  
**PROF. SHAHBAZ IQBAL KEHAR**  
M.B.B.S. (M. Path) (Path)  
Deptt. of Pathology  
Basic Medical Sciences Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Attestation of Sole Agent Certificate/distributorship letter from the concerned embassy.	<b>NO.</b>
Date of issuance of submitted sole agency certificate	May 15 <sup>th</sup> , 2017
Date of expiry of submitted sole agency certificate	May 15 <sup>th</sup> , 2020
Comments on the submitted sole agency certificate:	The issuance date of authorization letter i.e. May 15 <sup>th</sup> , 2017 shows that the letter is issued for specific tender and the bidder has not any past working experience with the Manufacture to ensure and testify the quality of Mortuary product.  The content of authorization letter is very simple and do not have the authenticity of issuance.
Original Equipment Manufacturer (OEM) certificate on the letter head of Manufacturer	Not submitted
Certificate from the Manufacturer that the offered equipment is in used in the country of origin and also the international reference list.	Not submitted.
Confirmation certificate on bidder's letter head regarding supply, installation, commissioning and Maintenance of Complete Cold Storage Mortuary System at installation sites.	Not submitted on letter head
Confirmation of post warranty Maintenance.	Not submitted
Confirmation of carrying out electrical and civil work/room renovation at installation site.	Not submitted
Confirmation of Three years free Service including spare parts from the date of installation.	Not submitted
Guarantee letter that the quoted Machinery / Equipment is the original / meet required specification	Submitted
List of hospitals/Institutions where bidder have received work order for the same Manufacturer Mortuary Equipment and completed the supply and installation.	From the attached references it is not cleared that the supplied mortuary at V-care Marton Road is from Mortuary solution or else.
Proof for the availability of workshop & trained engineers on the pay role of bidder for after sale service and installation.	Submitted
Undertaking from Manufacturer that if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work.	As per general and special condition of tender, bidder has not provided an undertaking

**Accounts Officer**  
Accountant General Sindh,  
Karachi.


SECTION OFFICER  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH


**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

**PROF. SHAHMAZ INOUB KHAN**  
M.B.E.S., M. PH.D.  
Deptt. of Pathology  
Basic Medical Sciences Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017*

	from Manufacturer i.e. M/s. Mortuary Solution, A- division Marston Engineer's Ltd, that "if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work"
Remarks :	<b>NON RESPONSIVE</b>

  
**Accounts Officer**  
 Accountant General Sindh  
 Karachi.

  
**SECTION OFFICER (PM&I)**  
 HEALTH DEPARTMENT.  
 GOVERNMENT OF SINDH

**DR. SYED AMIR RAZA**  
 Deputy Medical Superintendent  
 SMBB Trauma Centre  
 Civil Hospital, Karachi.

  
 Prof. Shahbaz Inqad Kehar

**PROF. SHAHBAZ INQAD KEHAR**  
 M.B.S.S. (M. Phil) (Path)  
 Dept. of Pathology  
 Basic Medical Sciences Institute,  
 Jinnah Postgraduate Medical Centre,  
 Karachi

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17**

**Technical Bid opened on May 19, 2017**

**TECHNICAL EVALUATION**

<b>Item no: 01 COLD STORAGE CABINET FOR FOUR BODY</b>	<b>M/s. Karachi Medical Company</b>
Model of quoted equipment	MSC-1-7
Make of quoted equipment:	Mortuary Solution, A- division Marston Engineer's Ltd
Country of origin: USA/UK/EEC/Japan	UK
Refrigerated Body Storage (4 Body Capacity)	Yes
Cabinet height: 2230-2260mm	As per sheet 2260mm
Cabinet Depth: 2230-2260mm	As per sheet 2300mm
Cabinet Width: 950-1210mm	As per sheet 1000mm
1 bay, 4 tier with wide trays.	Yes
White finish, 100mm thick, high density rigid polyurethane insulation.	Thickness is 80mm
304 Stainless Steel, 0.8mm to internal & external surfaces.	Not mentioned in brochure
Fully insulated floor structure, finished in 0.8-1mm thick stainless steel sheet.	Not mentioned in brochure
Trays should be supported with free running, 50mm self-bearing acetyl stub rollers.	Size of tray is not mentioned
1 x 4 tier chill temperature bays for compatible wide for a full height door not less than 650mm width single full height door for single entry operation (3°C to +5°C)	Door height is not mentioned
4 No. 304 grade stainless steel not less than 600mm wide trays.	Width of tray is not mentioned
Internal structure should consist of stainless steel open racking for an even temperature throughout the store and easy access for cleaning.	Not mentioned in brochure
High / low temperature alarm with volt free contact for connection to a BMS	Not mentioned
Initial refrigerant charge.	Yes
Door should internally clad for crash protection.	Not mentioned in brochure
1 No. rebated 'full height' insulated 100mm door with reinforced internal structure, size Not less than: 650 x 1000.	Not mentioned in brochure
Door heater tapes to each full height door.	Not mentioned
Door complete with "wipe clean" identity plate or drop in label holder.	Not mentioned
Profiled fully magnetic p.v.c door gasket in rebate to fully protect the seal.	Not mentioned
Lockable door latch.	Yes
Edge mount adjustable hinges should offer 180 deg or more opening.	Yes
Leading edges should be provided to prevent damage to trolley rollers	Yes
Full width stainless steel carrying handles	Yes

**Accounts Officer**  
Accountant General Sindh  
Karachi.

**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

**PROF. SHAHNAZ IQBAL KHAN**  
M.B.S., M. PH.D.  
Dept. of Pathology  
Basic Medical Sciences  
Jinnah Postgraduate Medical Centre,  
Karachi

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17**

**Technical Bid opened on May 19, 2017**

Roof mounted mono-block refrigeration system	Yes
3-5°C operating range in ambient of 32C to 50C .	Not mentioned
R404a refrigerant. Auto defrost.	Yes
Digital control panel with temp display and visual alarms.	Yes
Turning mortuary cabinet light on/off	No.
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 02 : - HYDRAULIC TROLLEY</b>	<b>M/s. Karachi Medical Company</b>
Model of quoted equipment	MSTM
Make of quoted equipment:	Mortuary Solution. A- division Marston Engineer's Ltd
Country of origin: USA/UK/EEC/Japan	UK
Hydraulic mortuary trolley	Yes
Robustly construction. heavy duty, square section, welded steel tube.	Yes
Stable and versatile platform for easy to move.	Yes
Simple to use and built. to withstand continual and heavy use.	Yes
Full width. free running PVC coated rollers.	Yes
Finished in steel material.	Not mentioned
4 No. 125mm braked castors. protective front bumpers	Yes
Reliable hydraulic system with dual action hydraulic hand pump or foot operated.	No- only hand pump
End handled with tray retaining mechanism.	Yes
Lift Height 300mm to 1650mm	400-1760mm
Dimensions: 650mm or more (W) x 2050mm or more (L) x 1050 or more (H) handle	580mm(W)x1835mm(L)x950mm(H)
Must be compatible with refrigeration cabinets.	Yes
Carrying weight 180kg or more.	Yes
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 03 : - COLD FOGGING MACHINE</b>	<b>M/s. Karachi Medical Company</b>
Model of quoted equipment	Triject 6208
Make of quoted equipment:	Fogmaster
Country of origin: USA/UK/EEC/Japan	USA
Rotatable fogging nozzles	Yes
Particle Size : 15-30 micron VMD, adjustable	Yes

**Accounts Officer**  
Accountant General Sindh,  
Karachi.

**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.


**PROF. SHAHNAZ IQBAL**  
M. Ed. S. M. Phil (Pain)  
Deptt. of Physiology  
Baski Medical Sciences Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi Page 5 of 42


*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*


**Technical Bid opened on May 19, 2017**

Tank Capacity: 2 liters or more	Yes
Liquid Flow Rate: 0-250ml/min, adjustable	Yes
Should be cable to handles both oil and water-based chemical solutions	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 04 : - CEILING FAN</b>	<b>M/s. Karachi Medical Company</b>
Make:	GFC – Pakistan
Size 56 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 05 : - EXHAUST FAN</b>	<b>M/s. Karachi Medical Company</b>
Make:	GFC-Pakistan
Size 18 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 06 : - STRETCHER WITH COVER</b>	<b>M/s. Karachi Medical Company</b>
Make:	Win industries-Pakistan
Dead body transport stretcher	Yes
Complete with cover and straps	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 07 : -STAINLESS STEEL TABLE</b>	<b>M/s. Karachi Medical Company</b>
Model of quoted equipment	MSGW
Make of quoted equipment:	Mortuary Solution, A- division Marston Engineer's ltd
Country of origin: USA/UK/EEC/Japan	UK
304 stainless steel table	Not mentioned in brochure
Dimensions: 2' (W) x 6.5' (L) x 4' (H)	Not mentioned in brochure
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 08 : -REVOLVING CHAIR</b>	<b>M/s. Karachi Medical Company</b>
Make:	Christer – Paksitan
Best quality.	Yes

  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

  
**SECTION OFFICER (PMB/II)**  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

  
**PROF. SHAFIQ UDDIN**  
Deptt. of Pathology  
Basic Medical Sciences Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*


**Technical Bid opened on May 19, 2017**

Seat and Back with cushion	Yes	
Arms tilting and Hydraulic Base	Yes	
Five Legs with 2 inch wheels	Yes	
<b>REMARKS</b>	<b>RESPONSIVE</b>	
<b><u>ITEM NO. 09 : -OFFICE TABLE</u></b>		
Make:	M/s. Karachi Medical Company	
Sheesham wood frame with lamination top with side rack, finished by spirit polish	Local	
with 3 draw Handle , locks , draw channel best quality	Yes	
size Length 42inch Width 24 Height 26 inch	Yes	
<b>REMARKS</b>	<b>RESPONSIVE</b>	
<b><u>ITEM NO. 10 : -VISITING CHAIR</u></b>		
Make:	M/s. Karachi Medical Company	
Chair with arms, Seat & Seatback.	Christer – Pakistan	
Minimum Dimensions : Width 20", Depth: 20", Height from seat: 18" (elegant design).	Yes	
<b>REMARKS</b>	<b>RESPONSIVE</b>	
A	<b>TRUNKEY BASIS PROJECT:</b> Confirmation regarding installation and Commissioning of complete Package of Cold Storage Machinery / Equipment and Furniture Fixture including all accessories for Strengthening of Mortuary Facility at All Teaching & major Hospitals in Sindh with six months starting from date of establishing L/c.	Yes
B	<b>MAINTENANCE WARRANTY</b> Confirmation of Maintenance of the machine/equipment during the whole period of warranty.	Warranty period is not mentioned
C	<b>OEM CERTIFICATE</b> Manufacture (OEM) certificate of equipment Manufacturer confirmation certificate that the machine / equipment being used in the country of origin.	Not attached
D	<b>TRAINING:</b> Confirmation regarding Training for operation of the cold storage system	Yes
E	<b>CIVIL AND ELECTRICAL WORK :</b> Confirmation for supply, installation, commissioning and Maintenance of complete Cold Storage for Mortuary including electrical and civil work/room renovation as per requirement of installation.	Yes
<b>REMARKS FOR COMPLETE BID ON TURNKEY BASIS :</b>		<b>NON-RESPONSIVE</b>

  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

  
SECTION OFFICER  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

  
**PROF. SHANZAI D KHAN**  
M.B.E.S. M. Phil (Path)  
Deptt. of Pathology  
Basic Medical Sciences Institute  
Jinnah Postgraduate Medical College  
Karachi



*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017*

M/S. TK MEDICAL INSTRUMENTS CO.


Annexure-II


BID EVALUATION

Bid Evaluation Criteria	M/s. TK Medical Instruments Co.
Bid is submitted as per SPP Rule 2010 (Amended 2013) clause 46(2) single stage two envelope bidding procedures.	Yes
Complete package/Turnkey solution	Yes
Original tender purchase receipt.	Yes
Photocopy of Bid security in shape of pay order.	Yes
Bid Validity : 90 days	Yes – 90 days
Compliance of tender terms and conditions, signed and stamped	Yes
Copy of Income Tax Certificate	Yes
Copy of GST Registration Certificate.	Yes
Copy of valid Professional Tax (Excise & Taxation) Certificate	Yes
Submission of Original catalogue of quoted items with technical bid from bidder.	Attached
Detail data sheet with essential technical and performance characteristics of the offered item on letter head of bidders.	Attached
Compliance of quality standard certificate	Attached
Sole Agency certificate:	Submitted
Attestation of Sole Agent Certificate/distributorship letter from the concerned embassy.	<b>NO.</b>
Date of issuance of submitted sole agency certificate	May 17 <sup>th</sup> , 2017
Date of expiry of submitted sole agency certificate	2 years from the date of issue
Comments on the submitted sole agency certificate:	The issuance date of authorization letter i.e. May 17 <sup>th</sup> , 2017 shows that the letter is issued for specific tender and the bidder has not any past working experience with the Manufacture to ensure and testify the quality of Mortuary product.

  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

  
**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

  
**PROF. SHAMMAZ NADEEM**  
S.B.S. M. PHIL(PH)  
Dept. of Technology  
Basic Medical Sciences Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi. Page 8 of 42

***Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh For the year 2016-17***  
**Technical Bid opened on May 19, 2017**

	The content of authorization letter is very simple and do not have the authenticity of issuance.
Original Equipment Manufacturer (OEM) certificate on the letter head of Manufacturer	Submitted
Certificate from the Manufacturer that the offered equipment is in used in the country of origin and also the international reference list.	Submitted
Confirmation certificate on bidder's letter head regarding supply, installation, commissioning and Maintenance of Complete Cold Storage Mortuary System at installation sites.	Not submitted on letter head
Confirmation of post warranty Maintenance.	Not submitted
Confirmation of carrying out electrical and civil work/room renovation at installation site.	Not submitted
Confirmation of Three years free Service including spare parts from the date of installation.	Not submitted
Guarantee letter that the quoted Machinery / Equipment is the original / meet required specification	Not submitted
List of hospitals/Institutions where bidder have received work order for the same Manufacturer Mortuary Equipment and completed the supply and installation.	Not submitted
Proof for the availability of workshop & trained engineers on the pay role of bidder for after sale service and installation.	List of staff is submitted but the experience in the field of Mortuary installation is not provided.
Undertaking from Manufacturer that if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work.	As per general and special condition of tender, bidder has not provided an undertaking from Manufacturer i.e. M/s. CEABIS -ITALY that "if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work"
Remarks:	<b>NON RESPONSIVE</b>

*Amir*  
**Accounts Officer**  
 Accountant General Sindh  
 Karachi.

**SECTION OFFICER (PM&H)**  
 HEALTH DEPARTMENT  
 GOVERNMENT OF SINDH

*Amir*  
**DR. SYED AMIR RAZA**  
 Deputy Medical Superintendent  
 SMBB Trauma Centre  
 Civil Hospital, Karachi.

*Siddiq*  
**PROF. SHAHMAZ IMDAD KHAN**  
 M.B.B.S. & M.D. Path (Path)  
 Deptt. of Pathology  
 Jinnah Postgraduate Medical Centre,  
 Karachi

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17**

**Technical Bid opened on May 19, 2017**

**TECHNICAL EVALUATION**

<b>Item no: 01 COLD STORAGE CABINET FOR FOUR BODY</b>	<b>M/s. TK Medical Instruments Co.</b>
Model of quoted equipment	CEA CA-15
Make of quoted equipment:	CEABIS
Country of origin: USA/UK/EEC/Japan	Italy
Refrigerated Body Storage (4 Body Capacity)	Yes
Cabinet height: 2230-2260mm	As mentioned on letter head is 2260mm
Cabinet Depth: 2230-2260mm	As mentioned on letter head is 2260mm
Cabinet Width: 950-1210mm	As mentioned on letter head is 1020mm
1 bay, 4 tier with wide trays.	Yes
White finish, 100mm thick, high density rigid polyurethane insulation.	Thickness is 80mm
304 Stainless Steel, 0.8mm to internal & external surfaces.	0.6mm , as per attached brochure.
Fully insulated floor structure, finished in 0.8-1mm thick stainless steel sheet.	Not mentioned in brochure
Trays should be supported with free running, 50mm self-bearing acetyl stub rollers.	Not mentioned in brochure
1 x 4 tier chill temperature bays for compatible wide for a full height door not less than 650mm width single full height door for single entry operation (3°C to +5°C)	Door height is not mentioned
4 No. 304 grade stainless steel not less than 600mm wide trays.	Width of tray is not mentioned in brochure.
Internal structure should consist of stainless steel open racking for an even temperature throughout the store and easy access for cleaning.	Not mentioned in brochure
High / low temperature alarm with volt free contact for connection to a BMS	Yes
Initial refrigerant charge.	Yes
Door should internally clad for crash protection.	Yes
1 No. rebated 'full height' insulated 100mm door with reinforced internal structure , size Not less than: 650 x 2000.	Door dimension in not mentioned in brochure
Door heater tapes to each full height door.	Not mentioned in brochure
Door complete with "wipe clean" identity plate or drop in label holder.	Not mentioned in brochure
Profiled fully magnetic p.v.c door gasket in rebate to fully protect the seal.	Yes
Breakable door latch.	Yes

**Accounts Officer**  
Accountant General Sindh,  
Karachi.

*(Signature)*

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*(Signature)*

PROF. SYED AMIR RAZA  
Deputy Medical Superintendent  
Sindh Medical Super Speciality Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**For the year 2016-17**

**Technical Bid opened on May 19, 2017**

Edge mount adjustable hinges should offer 180 deg or more opening.	Not mentioned in brochure
Leading edges should be provided to prevent damage to trolley rollers	Yes
Full width stainless steel carrying handles	Yes
Roof mounted mono-block refrigeration system	Not mentioned in brochure
3-5°C operating range in ambient of 32C to 50C .	-5° ~ +5°C, ambient temp is not mentioned.
R404a refrigerant, Auto defrost.	Not mentioned in brochure
Digital control panel with temp display and visual alarms.	Yes
Turning mortuary cabinet light on/off	Yes
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 02 :- HYDRAULIC TROLLEY</b>	<b>M/s. TK Medical Instruments Co.</b>
Model of quoted equipment	CEA C028
Make of quoted equipment:	Ceabis
Country of origin: USA/UK/EEC/Japan	Italy
Hydraulic mortuary trolley	Yes
Robustly construction, heavy duty, square section, welded steel tube.	Yes
Stable and versatile platform for easy to move.	Yes
Simple to use and built, to withstand continual and heavy use.	Yes
Full width, free running PVC coated rollers.	Yes
Finished in steel material.	Yes
4 No, 125mm braked castors, protective front bumpers	Yes
Reliable hydraulic system with dual action hydraulic hand pump or foot operated.	No- only single action by foot.
End handled with tray retaining mechanism.	Yes
Lift Height 300mm to 1650mm	400-2020mm
Dimensions: 650mm or more (W) x 2050mm or more (L) x 1050 or more (H) handle	720mm(W) x 2340mm(L) x 1020mm (H)
Must be compatible with refrigeration cabinets.	Yes
Carrying weight 180kg or more.	Yes
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 03 :- COLD FOGGING MACHINE</b>	<b>M/s. TK Medical Instruments Co.</b>
Model of quoted equipment	Triject 6208

*Accountants Office*  
**Accountant General Sindh**  
 Karachi.

**SECTION OFFICER (PIM&I)**  
 HEALTH DEPARTMENT  
 GOVERNMENT OF SINDH

**DR. SYED AMIR RAZA**  
 Deputy Medical Superintendent  
 SMBB Trauma Centre  
 Civil Hospital, Karachi.

**PROF. SHAHNAZ IMDAD KEHAR**  
 M.B.E.S. M. Phil (Path)  
 Deptt. of Pathology  
 Basic Medical Sciences Institute  
 Postgraduate Medical Council  
 Karachi

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Make of quoted equipment:	Fogmaster
Country of origin: USA/UK/EEC/Japan	USA
Rotatable fogging nozzles	Yes
Particle Size : 15-30 micron VMD. adjustable	Yes
Tank Capacity: 2 liters or more	Yes
Liquid Flow Rate: 0-250ml/min, adjustable	Yes
Should be cable to handles both oil and water-based chemical solutions	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 04 : - CEILING FAN</b>	
Make:	M/s. TK Medical Instruments Co.
Size 56 inch	Pak fan – Pakistan
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 05 : - EXHAUST FAN</b>	
Make:	M/s. TK Medical Instruments Co.
Size 18 inch	Pak Fan-Pakistan
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 06 : - STRETCHER WITH COVER</b>	
Make:	M/s. TK Medical Instruments Co.
	Not mentioned- brochure is not attached hence required specification cannot be confirmed.
Dead body transport stretcher	Yes
Complete with cover and straps	Yes
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 07 : -STAINLESS STEEL TABLE</b>	
Model of quoted equipment	M/s. TK Medical Instruments Co.
Make of quoted equipment:	CEA TA 01
Country of origin: USA/UK/EEC/Japan	Ceabis
14 stainless steel table	Italy
	Yes

*Accounts Officer*  
Accountant General Sindh,  
Karachi.

*[Signature]*

SECTION OFFICER (PM&H)  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*[Signature]*

PROF. SHAHBAZ IMDAD KEMAR  
S.B.S.H. (PM&H)  
Director  
Health Department  
Government of Sindh  
Karachi

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Dimensions: 2' (W) x 6.5' (L) x 4' (H)	As per brochure 2.4' (W) x 6.8' (L) x 2.8' (H)
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 08 : -REVOLVING CHAIR</b>	<b>M M/s. TK Medical Instruments Co.</b>
Make:	Local – brochure not submitted
Rexene best Quality.	Yes
Seat and Back with cushion	Yes
Arms tilting and Hydraulic Base	Yes
Five Legs with 2 inch wheels	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 09 : -OFFICE TABLE</b>	<b>M/s. TK Medical Instruments Co.</b>
Make:	Local – brochure not submitted
Sheesham wood frame with lamination top with side rack, finished by spirit polish	Yes
with 3 draw Handle , locks , draw channel best quality	Yes
size Length 42inch Width 24 Height 26 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 10 : -VISITING CHAIR</b>	<b>M/s. TK Medical Instruments Co.</b>
Make:	Local – brochure not submitted
Chair with arms, Seat & Seatback.	Yes
Minimum Dimensions : Width 20", Depth: 20", Height from seat: 18" (elegant design).	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
A	<b>TRUNKEY BASIS PROJECT:</b> Confirmation regarding installation and Commissioning of complete Package of Cold Storage Machinery / Equipment and Furniture Fixture including all accessories for Strengthening of Mortuary Facility at All Teaching & major Hospitals in Sindh with six months starting from date of establishing L/c.
	Not submitted
B	<b>MAINTENANCE WARRANTY</b> Confirmation of Maintenance of the machine/equipment during the whole period of warranty.
	Not submitted

*Accountant General Sindh,  
Karachi.*

*SECTION OFFICER (M&B)  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH*

*DR. SYED AMIR RAZA  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.*

*PROF. SHAHMAZ IQDAD KEHAR  
M.E.S., M. PHIL (Path)  
Deptt. of Pathology  
Basic Medical Sciences Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi*

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh*

*For the year 2016-17*

Technical Bid opened on May 19, 2017


C	<b>OEM CERTIFICATE</b> Manufacture (OEM) certificate of equipment Manufacturer confirmation certificate that the machine / equipment being used in the country of origin.	Submitted
D	<b>TRAINING:</b> Confirmation regarding Training for operation of the cold storage system	Not submitted
E	<b>CIVIL AND ELECTRICAL WORK :</b> Confirmation for supply, installation, commissioning and Maintenance of complete Cold Storage for Mortuary including electrical and civil work/room renovation as per requirement of installation.	Not submitted
<b>REMARKS FOR COMPLETE BID ON TURNKEY BASIS :</b>		<b>NON-RESPONSIVE</b>

  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.



SECRETARY  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.



**PROF. SHAMIM ZINBAC KHAN**  
MBBS, MCh, FRCR (Paed)  
Dr. Shaukat Ali Khan Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi

**Tender for provision, installation and commissioning of Cold storages, Machinery/ Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh For the year 2016-17**  
**Technical Bid opened on May 19, 2017**

**M/s. BIOS**

**Annexure-III**

**BID EVALUATION**

<b>Bid Evaluation Criteria</b>	<b>M/s. BIOS</b>
Bid is submitted as per SPP Rule 2010 (Amended 2013) clause 46(2) single stage two envelope bidding procedures.	Yes
Complete package/Turnkey solution	Yes
Original tender purchase receipt.	Yes
Photocopy of Bid security in shape of pay order.	Yes
Bid Validity : 90 days	Yes – 90 days
Compliance of tender terms and conditions, signed and stamped	Yes
Copy of Income Tax Certificate	Yes
Copy of GST Registration Certificate.	Yes
Copy of valid Professional Tax (Excise & Taxation) Certificate	Yes
Submission of Original catalogue of quoted items with technical bid from bidder.	Submitted
Detail data sheet with essential technical and performance characteristics of the offered item on letter head of bidders.	Submitted
Compliance of quality standard certificate	Submitted
Sole Agency certificate:	Submitted
Attestation of Sole Agent Certificate/distributorship letter from the concerned embassy.	Not attested from Embassy but a undertaking from Manufacturer is enclosed, stating that the legal representative of Manufacturer has already submitted the letter for Attestation in Embassy in London. Prior to attestation the submitted authorization letter has been attested by Notary officials and the East Midland Chamber of Commerce.
Date of issuance of submitted sole agency certificate	Aug 11 <sup>th</sup> , 2016
Date of expiry of submitted sole agency certificate	Aug 10 <sup>th</sup> , 2019

*[Signature]*  
**Accounts Officer**  
 Accountant General Sindh,  
 Karachi.

*[Signature]*  
 SECTION OFFICER  
 HELATH DEPARTMENT  
 GOVERNMENT OF SINDH

*[Signature]*  
**DR. SYED AMIR RAZA**  
 Deputy Medical Superintendent  
 SMBB Trauma Centre  
 Civil Hospital, Karachi.


*[Signature]*

*[Signature]*  
 FROM: SYED AMIR RAZA, DR. SYED AMIR RAZA  
 Director of Pathology  
 Base Medical Sciences Institute,  
 Jinnah Postgraduate Medical Centre,  
 Karachi.




**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017**

Comments on the submitted sole agency certificate:	The content of the letter is complete and accepted.
Original Equipment Manufacturer (OEM) certificate on the letter head of Manufacturer	Submitted
Certificate from the Manufacturer that the offered equipment is in used in the country of origin and also the international reference list.	Submitted
Confirmation certificate on bidder's letter head regarding supply, installation, commissioning and Maintenance of Complete Cold Storage Mortuary System at installation sites.	Submitted
Confirmation of post warranty Maintenance.	Submitted
Confirmation of carrying out electrical and civil work/room renovation at installation site.	Submitted
Confirmation of Three years free Service including spare parts from the date of installation.	Submitted
Guarantee letter that the quoted Machinery / Equipment is the original / meet required specification	Submitted
List of hospitals/Institutions where bidder have received work order for the same Manufacturer Mortuary Equipment and completed the supply and installation.	Two reference are provided from bidder that the quoted Manufacturer's items are supplied and installed at Civil Hospital-Karachi and Jinnah Postgraduate Medical Center-Karachi
Proof for the availability of workshop & trained engineers on the pay role of bidder for after sale service and installation.	List of technical engineers and picture of workshop are submitted.
Undertaking from Manufacturer that if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work.	Submitted
Remarks :	<b>RESPONSIVE</b>

  
**Accountant General Sindh,**  
Karachi.

  
**SECTION OFFICER (P/M&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
**SMBB Trauma Centre**  
Civil Hospital, Karachi.

  
**PROF. SHABBIR AZIM**  
Near S. B. P. Hospital  
Dept. of Pathology  
Jinnah Postgraduate Medical Centre,  
Karachi

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh For the year 2016-17*

**Technical Bid opened on May 19, 2017**

**TECHNICAL EVALUATION**

<b>Item no: 01 COLD STORAGE CABINET FOR FOUR BODY</b>	<b>M/s. BIOS</b>
Model of quoted equipment	FDC 1-4
Make of quoted equipment:	LEEC
Country of origin: USA/UK/EEC/Japan	UK
Refrigerated Body Storage (4 Body Capacity)	Yes
Cabinet height: 2230-2260mm	2300mm
Cabinet Depth: 2230-2260mm	2300mm
Cabinet Width: 950-1210mm	960mm
1 bay, 4 tier with wide trays.	Yes
White finish, 100mm thick, high density rigid polyurethane insulation.	Yes
304 Stainless Steel, 0.8mm to internal & external surfaces.	Finished in 0.9mm SS
Fully insulated floor structure, finished in 0.8-1mm thick stainless steel sheet.	0.9mm SS
Trays should be supported with free running, 50mm self-bearing acetyl stub rollers.	Yes
1 x 4 tier chill temperature bays for compatible wide for a full height door not less than 650mm width single full height door for single entry operation (3°C to +5°C)	Yes - Door width 700mm
4 No. 304 grade stainless steel not less than 600mm wide trays.	Yes- 660., SS. Trays
Internal structure should consist of stainless steel open racking for an even temperature throughout the store and easy access for cleaning.	Yes
High / low temperature alarm with volt free contact for connection to a BMS	Yes
Initial refrigerant charge.	Not mentioned in brochure but confirmed in bidder's quotation.
Door should internally clad for crash protection.	Not mentioned in brochure
1 No. rebated 'full height' insulated 100mm door with reinforced internal structure , size Not less than: 650 x 2000.	Single rebated and reinforced 100mm door is mentioned in brochure. Size of door in brochure is 700 x 2050mm
Door heater tapes to each full height door.	Not mentioned in brochure
Door complete with "wipe clean" identity plate or drop in label holder.	Yes
Profiled fully magnetic p.v.c door gasket in rebate to fully protect the seal.	Yes
Lockable door latch.	Yes

*Accounts Officer*  
Accountant General Sindh,  
Karachi.

*SECTION OFFICER*  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

*DR. SYED AMIR RAZA*  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh*

*For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Edge mount adjustable hinges should offer 180 deg or more opening.	Yes
Leading edges should be provided to prevent damage to trolley rollers	Yes
Full width stainless steel carrying handles	Not mentioned in brochure
Roof mounted mono-block refrigeration system	Yes
3-5°C operating range in ambient of 32C to 50C .	Yes
R404a refrigerant, Auto defrost.	Yes
Digital control panel with temp display and visual alarms.	Yes
Turning mortuary cabinet light on/off	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 02 : - HYDRAULIC TROLLEY</b>	<b>M/s. BIOS</b>
Model of quoted equipment	MF
Make of quoted equipment:	LEEC
Country of origin: USA/UK/EEC/Japan	UK
Hydraulic mortuary trolley	Yes
Robustly construction, heavy duty, square section, welded steel tube.	Yes
Stable and versatile platform for easy to move.	Yes
Simple to use and built. to withstand continual and heavy use.	Yes
Full width, free running PVC coated rollers.	Yes
Finished in steel material.	Yes
4 No. 125mm braked castors, protective front bumpers	Yes
Reliable hydraulic system with dual action hydraulic hand pump or foot operated.	Yes
End handled with tray retaining mechanism.	Yes
Lift Height 300mm to 1650mm	390-1780mm
Dimensions: 650mm or more (W) x 2050mm or more (L) x 1050 or more (H) handle	2070mm(L) x 1070mm(H) Width not mentioned in brochure. 655mm(W), Mentioned in Manufacturer's technical details
Must be compatible with refrigeration cabinets.	Yes
Carrying weight 180kg or more.	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>

*[Signature]*  
**Accounts Officer**  
 Accountant General Sindh  
 Karachi.

*[Signature]*  
**SECTION OFFICER (PM&I)**  
 HEALTH DEPARTMENT,  
 GOVERNMENT OF SINDH

*[Signature]*  
**PROF. SHAHNAZ IMDAD KEMAR**  
 M.B.E.S., M.Phil (Pathology)  
 Director of Pathology  
 Sindh Government Laboratories Institute,  
 Jinnah Postgraduate Medical Centre,  
 Karachi.

*[Signature]*  
**DR. SYED AMIR RAZA**  
 Deputy Medical Superintendent  
 SMBB Trauma Centre  
 Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

<b>ITEM NO. 03 : - COLD FOGGING MACHINE</b>	<b>M/s. BIOS</b>
Model of quoted equipment	Trijet 6208
Make of quoted equipment:	Fogmaster
Country of origin: USA/UK/EEC/Japan	USA
Rotatable fogging nozzles	Yes
Particle Size : 15-30 micron VMD, adjustable	Yes
Tank Capacity: 2 liters or more	Yes
Liquid Flow Rate: 0-250ml/min, adjustable	Yes
Should be cable to handles both oil and water-based chemical solutions	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 04 : - CEILING FAN</b>	<b>M/s. BIOS</b>
<b>Make:</b>	Pak fan – Pakistan brochure submitted
Size 56 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 05 : - EXHAUST FAN</b>	<b>M/s. BIOS</b>
<b>Make:</b>	Pak Fan-Pakistan brochure submitted
Size 18 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 06 : - STRETCHER WITH COVER</b>	<b>M/s. BIOS</b>
<b>Make:</b>	Local brochure submitted
Dead body transport stretcher	Yes
Complete with cover and straps	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 07 : -STAINLESS STEEL TABLE</b>	<b>M/s. BIOS.</b>
Model of quoted equipment	RTF
Make of quoted equipment	LEEC

*Amir*  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

*AK*  
**SECTION OFFICER (PM/2)**  
HEALTH AND FAMILY WELFARE  
GOVERNMENT OF SINDH

*Saleem*  
**PROF. SHAMAZ KHAN**  
M.B.B.S. (M. Phil) (Gosh)  
Dept. of Pathology  
Bande Medical Sciences Institute,  
Jinnah Postgraduate Medical Centre  
(Karachi)




**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Country of origin: USA/UK/EEC/Japan	UK
304 stainless steel table	Yes
Dimensions: 2' (W) x 6.5' (L) x 4' (H)	Not mentioned in brochure but mentioned in Manufacturer's technical data sheet as : 660mm(W) x 2100mm(L) x 850mm(H)
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 08 : -REVOLVING CHAIR</b>	<b>M/s. BIOS</b>
Make:	Local – brochure submitted
Rexene best Quality.	Yes
Seat and Back with cushion	Yes
Arms tilting and Hydraulic Base	Yes
Five Legs with 2 inch wheels	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 09 : -OFFICE TABLE</b>	<b>M/s. BIOS</b>
Make:	Local – brochure submitted
Sheesham wood frame with lamination top with side rack, finished by spirit polish	Yes
with 3 draw Handle , locks , draw channel best quality	Yes
size Length 42inch Width 24 Height 26 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 10 : -VISITING CHAIR</b>	<b>M/s. BIOS</b>
Make:	Local – brochure submitted
Chair with arms, Seat & Seatback.	Yes
Minimum Dimensions : Width 20", Depth: 20", Height from seat: 18" (elegant design).	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>TRUNKEY BASIS PROJECT:</b> Confirmation regarding installation and Commissioning of complete Package of Cold Storage Machinery / Equipment and Furniture Fixture including all accessories for Strengthening of Mortuary Facility at All Teaching & major Hospitals in Sindh with six months starting from date of establishing L/c.	Submitted

Accounts Officer  
Accountant General Sindh  
Karachi

PROF. SHANAZ IQBAL KHAN  
M.B.B.S., M. Phil (Peds)  
Deptt. of Paediatrics  
Ehsa Medical Sciences Institute  
Jinnah Postgraduate Medical Centre,  
Karachi

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh*

*For the year 2016-17*

**Technical Bid opened on May 19, 2017**

B	<b>MAINTENANCE WARRANTY</b> Confirmation of Maintenance of the machine/equipment during the whole period of warranty.	Submitted
C	<b>OEM CERTIFICATE</b> Manufacture (OEM) certificate of equipment Manufacturer confirmation certificate that the machine / equipment being used in the country of origin.	Submitted
D	<b>TRAINING:</b> Confirmation regarding Training for operation of the cold storage system	Submitted
E	<b>CIVIL AND ELECTRICAL WORK :</b> Confirmation for supply, installation, commissioning and Maintenance of complete Cold Storage for Mortuary including electrical and civil work/room renovation as per requirement of installation.	Submitted
<b>REMARKS FOR COMPLETE BID ON TURNKEY BASIS :</b>		<b>RESPONSIVE</b>

  
**Accounts Officer**  
Accountant General Sindh  
Karachi.

  
**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT.  
GOVERNMENT OF SINDH

  
**PROC. OFFICER**  
Dept. of Procurement  
State Medical Services Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi

  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017*

M/s. Maha Trading

Annexure-IV

BID EVALUATION

Bid Evaluation Criteria	M/s. Maha Trading
Bid is submitted as per SPP Rule 2010 (Amended 2013) clause 46(2) single stage two envelope bidding procedures.	Yes
Complete package/Turnkey solution	Yes
Original tender purchase receipt.	Yes
Photocopy of Bid security in shape of pay order.	Personal Cheque no. 29303694 from JS – Bank, Model Town Branch – Lahore is submitted instead of pay order.
Bid Validity : 90 days	Not mentioned
Compliance of tender terms and conditions, signed and stamped	Yes
Copy of Income Tax Certificate	Yes
Copy of GST Registration Certificate.	Yes
Copy of valid Professional Tax (Excise & Taxation) Certificate	Yes
Submission of Original catalogue of quoted items with technical bid from bidder.	Yes
Detail data sheet with essential technical and performance characteristics of the offered item on letter head of bidders.	Yes
Compliance of quality standard certificate	Yes
Sole Agency certificate:	Submitted
Attestation of Sole Agent Certificate/distributorship letter from the concerned embassy.	NO
Date of issuance of submitted sole agency certificate	May 17 <sup>th</sup> , 2017
Date of expiry of submitted sole agency certificate	Not mentioned
Comments on the submitted sole agency certificate:	The submitted authorization letter is only for Province of Punjab since 2015. The validity of submitted authorization letter is not mentioned.
Original Equipment Manufacturer (OEM) certificate on the letter head of Manufacturer	Not submitted

Accounts Officer  
Accountant General Sindh  
Karachi.

*[Handwritten Signature]*

*[Handwritten Signature]*

SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

*[Handwritten Signature]*

DR. SYED AMIR RAZA  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Certificate from the Manufacturer that the offered equipment is in used in the country of origin and also the international reference list.	Not submitted
Confirmation certificate on bidder's letter head regarding supply, installation, commissioning and Maintenance of Complete Cold Storage Mortuary System at installation sites.	Not submitted
Confirmation of post warranty Maintenance.	Not submitted
Confirmation of carrying out electrical and civil work/room renovation at installation site.	Not submitted
Confirmation of Three years free Service including spare parts from the date of installation.	Not submitted
Guarantee letter that the quoted Machinery / Equipment is the original / meet required specification	Not submitted
List of hospitals/Institutions where bidder have received work order for the same Manufacturer Mortuary Equipment and completed the supply and installation.	Not submitted
Proof for the availability of workshop & trained engineers on the pay role of bidder for after sale service and installation.	Submitted
Undertaking from Manufacturer that if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work.	Not submitted
Remarks :	<b>NON- RESPONSIVE</b> The bid security is not provided in shape of pay order/Demand draft, hence the bid of M/s. Maha Trading is <b>Rejected</b> .

*[Signature]*  
**Accounts Officer**  
Accountant General Sindh  
Karachi.

*[Signature]*  
**SECTION OFFICER (PMS&I)**  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

*[Signature]*  
**PROF. SHARAFUZZAMAN D. VESPIER**  
FRCR (Paed) FRCR (Paed) FRCR (Paed)  
Deputy Medical Superintendent  
Civil Medical Services Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi

*[Signature]*  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.



**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17**

**Technical Bid opened on May 19, 2017**

**TECHNICAL EVALUATION**

<b>Item no: 01 COLD STORAGE CABINET FOR FOUR BODY</b>	
Model of quoted equipment	
Make of quoted equipment:	
Country of origin: USA/UK/EEC/Japan	
Refrigerated Body Storage (4 Body Capacity)	
Cabinet height: 2230-2260mm	
Cabinet Depth: 2230-2260mm	
Cabinet Width: 950-1210mm	
1 bay, 4 tier with wide trays.	
White finish, 100mm thick, high density rigid polyurethane insulation.	
304 Stainless Steel, 0.8mm to internal & external surfaces.	
Fully insulated floor structure, finished in 0.8-1mm thick stainless steel sheet.	
Trays should be supported with free running, 50mm self-bearing acetyl stub rollers.	
1 x 4 tier chill temperature bays for compatible wide for a full height door not less than 650mm width single full height door for single entry operation (3°C to +5°C)	
4 No. 304 grade stainless steel not less than 600mm wide trays.	
Internal structure should consist of stainless steel open racking for an even temperature throughout the store and easy access for cleaning.	
High / low temperature alarm with volt free contact for connection to a BMS	
Initial refrigerant charge.	
Door should internally clad for crash protection.	
1 No. rebated 'full height' insulated 100mm door with reinforced internal structure , size Not less than: 650 x 2000.	
Door heater tapes to each full height door.	
Door complete with "wipe clean" identity plate or drop in label holder.	
Profiled fully magnetic p.v.c door gasket in rebate to fully protect the seal.	
Lockable door latch.	
Edge mount adjustable hinges should offer 180 deg or more opening.	
Leading edges should be provided to prevent damage to trolley rollers	
Full width stainless steel carrying handles	
Roof mounted mono-block refrigeration system	
	Bid is not qualify for technical evaluation.

Accounts Office  
Accountant General  
Karachi

SECTION OFFICER (MORTUARY)  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

DR. SYED AMIR RAZA  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Hospital, Karachi

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**For the year 2016-17**

**Technical Bid opened on May 19, 2017**

3-5°C operating range in ambient of 32C to 50C.	
R404a refrigerant, Auto defrost.	
Digital control panel with temp display and visual alarms.	
Turning mortuary cabinet light on/off	
<b>REMARKS</b>	
<b><u>ITEM NO. 02 : - HYDRAULIC TROLLEY</u></b>	
Model of quoted equipment	
Make of quoted equipment:	
Country of origin: USA/UK/EEC/Japan	
Hydraulic mortuary trolley	
Robustly construction, heavy duty, square section, welded steel tube.	
Stable and versatile platform for easy to move.	
Simple to use and built, to withstand continual and heavy use.	
Full width, free running PVC coated rollers.	
Finished in steel material.	
4 No. 125mm braked castors, protective front bumpers	
Reliable hydraulic system with dual action hydraulic hand pump or foot operated.	
End handled with tray retaining mechanism.	
Lift Height 300mm to 1650mm	
Dimensions: 650mm or more (W) x 2050mm or more (L) x 1050 or more (H) handle	
Must be compatible with refrigeration cabinets.	
Carrying weight 180kg or more.	
<b>REMARKS</b>	Bid is not qualify for technical evaluation.
<b><u>ITEM NO. 03 : - COLD FOGGING MACHINE</u></b>	
Model of quoted equipment	
Make of quoted equipment:	
Country of origin: USA/UK/EEC/Japan	
Rotatable fogging nozzles	
Particle Size : 15-30 micron VMD, adjustable	
Tank Capacity: 2 liters or more	
<b>REMARKS</b>	Bid is not qualify for technical evaluation.

**Accounts Officer**  
Accountant General  
Karachi

**SECTION OFFICER (PM&H)**  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

**DR. SHAHNAZ IMDAD KEHAR**  
A.B.S. M. PHM(Fest)  
Centre of Excellence  
Basic Medical Sciences Institute,  
Health Postgraduate Medical Centre,  
Karachi

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Liquid Flow Rate: 0-250ml/min, adjustable	
Should be cable to handles both oil and water-based chemical solutions	
<b>REMARKS</b>	
<b><u>ITEM NO. 04 : - CEILING FAN</u></b>	
Make:	Bid is not qualify for technical evaluation.
Size 56 inch	
<b>REMARKS</b>	
<b><u>ITEM NO. 05 : - EXHAUST FAN</u></b>	
Make:	Bid is not qualify for technical evaluation.
Size 18 inch	
<b>REMARKS</b>	
<b><u>ITEM NO. 06 : - STRETCHER WITH COVER</u></b>	
Make:	Bid is not qualify for technical evaluation.
Dead body transport stretcher	
Complete with cover and straps	
<b>REMARKS</b>	
<b><u>ITEM NO. 07 : -STAINLESS STEEL TABLE</u></b>	
Model of quoted equipment	Bid is not qualify for technical evaluation.
Make of quoted equipment:	
Country of origin: USA/UK/EEC/Japan	
304 stainless steel table	
Dimensions: 2' (W) x 6.5' (L) x 4' (H)	
<b>REMARKS</b>	
<b><u>ITEM NO. 08 : -REVOLVING CHAIR</u></b>	
Make:	Bid is not qualify for technical evaluation.
Rexene best Quality.	

*Amir*  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

*ST*  
**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

*Sulag*  
**DR. SYED AMIR RAZA**  
M.B.S.S, (M.Phil) (Poli)  
Deptt: of Pertheology  
Basic Medical Sciences Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi

*Amir*  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
ital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh*

*For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Seat and Back with cushion		
Arms tilting and Hydraulic Base		
Five Legs with 2 inch wheels		
<b>REMARKS</b>		
<b>ITEM NO. 09 : -OFFICE TABLE</b>	Bid is not qualify for technical evaluation.	
Make:		
Sheesham wood frame with lamination top with side rack, finished by spirit polish with 3 draw Handle , locks , draw channel best quality		
size Length 42inch Width 24 Height 26 inch		
<b>REMARKS</b>		
<b>ITEM NO. 10 : -VISITING CHAIR</b>	Bid is not qualify for technical evaluation.	
Make:		
Chair with arms, Seat & Seatback.		
Minimum Dimensions : Width 20", Depth: 20", Height from seat: 18" (elegant design).		
<b>REMARKS</b>		
A	<b>TURNKEY BASIS PROJECT:</b> Confirmation regarding installation and Commissioning of complete Package of Cold Storage Machinery / Equipment and Furniture Fixture including all accessories for Strengthening of Mortuary Facility at All Teaching & major Hospitals in Sindh with six months starting from date of establishing L/c.	Bid is not qualify for technical evaluation.
B	<b>MAINTENANCE WARRANTY</b> Confirmation of Maintenance of the machine/equipment during the whole period of warranty.	
C	<b>OEM CERTIFICATE</b> Manufacture (OEM) certificate of equipment Manufacturer confirmation certificate that the machine / equipment being used in the country of origin.	
D	<b>TRAINING:</b> Confirmation regarding Training for operation of the cold storage system	
E	<b>CIVIL AND ELECTRICAL WORK :</b> Confirmation for supply, installation, commissioning and Maintenance of complete Cold Storage for Mortuary including electrical and civil work/room renovation as per requirement of installation.	
<b>REMARKS FOR COMPLETE BID ON TURNKEY BASIS :</b>		<b>NON-RESPONSIVE</b>

*Lawing*  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

*SO*  
**SECTION OFFICER (P.M.)**  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

**PROF. SHANNOZ IQBAL KHAN**  
M.B.B.S. (F.M.S.S.)  
Dip. in Forensic Medicine  
Dip. in Legal Medicine  
Dip. in Toxicology  
Dip. in Pathology  
Dip. in Microbiology  
Dip. in Immunology  
Dip. in Ophthalmology  
Dip. in Dermatology  
Dip. in Venereology  
Dip. in Geriatrics  
Dip. in Rheumatology  
Dip. in Nephrology  
Dip. in Endocrinology  
Dip. in Hematology  
Dip. in Oncology  
Dip. in Cardiology  
Dip. in Neurology  
Dip. in Pediatrics  
Dip. in Obstetrics  
Dip. in Gynecology  
Dip. in Radiology  
Dip. in Anesthesiology  
Dip. in Intensive Care  
Dip. in Critical Care  
Dip. in Palliative Care  
Dip. in Geriatric Medicine  
Dip. in Geriatric Psychiatry  
Dip. in Geriatric Neurology  
Dip. in Geriatric Orthopedics  
Dip. in Geriatric Ophthalmology  
Dip. in Geriatric Otorhinolaryngology  
Dip. in Geriatric Urology  
Dip. in Geriatric Gynecology  
Dip. in Geriatric Hematology  
Dip. in Geriatric Oncology  
Dip. in Geriatric Cardiology  
Dip. in Geriatric Neurology  
Dip. in Geriatric Pediatrics  
Dip. in Geriatric Obstetrics  
Dip. in Geriatric Gynecology  
Dip. in Geriatric Radiology  
Dip. in Geriatric Anesthesiology  
Dip. in Geriatric Intensive Care  
Dip. in Geriatric Critical Care  
Dip. in Geriatric Palliative Care

*DR. SYED AMIR RAZA*  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017*

M/s. Medline Technologies (Pvt.) Ltd

Annexure-V

**BID EVALUATION**

Bid Evaluation Criteria	M/s. Medline Technologies (Pvt.) Ltd
Bid is submitted as per SPP Rule 2010 (Amended 2013) clause 46(2) single stage two envelope bidding procedures.	Yes
Complete package/Turnkey solution	Yes
Original tender purchase receipt.	Yes
Photocopy of Bid security in shape of pay order.	Yes
Bid Validity : 90 days	Yes – 90 days
Compliance of tender terms and conditions, signed and stamped	Yes
Copy of Income Tax Certificate	Yes
Copy of GST Registration Certificate.	Yes
Copy of valid Professional Tax (Excise & Taxation) Certificate	Yes
Submission of Original catalogue of quoted items with technical bid from bidder.	Submitted
Detail data sheet with essential technical and performance characteristics of the offered item on letter head of bidders.	Submitted
Compliance of quality standard certificate	Submitted
Sole Agency certificate:	Submitted
Attestation of Sole Agent Certificate/distributorship letter from the concerned embassy.	No
Date of issuance of submitted sole agency certificate	May 18 <sup>th</sup> , 2017
Date of expiry of submitted sole agency certificate	Dec 31 <sup>st</sup> , 2019
Comments on the submitted sole agency certificate:	The letter is complete and accepted.
Original Equipment Manufacturer (OEM) certificate on the letter head of Manufacturer	Submitted
Certificate from the Manufacturer that the offered equipment is in used in the country of origin and also the international reference list.	Submitted
Confirmation certificate on bidder's letter head regarding supply, installation, commissioning and Maintenance of Complete Cold Storage Mortuary System at installation sites.	Submitted
Confirmation of Post Warranty Maintenance.	Submitted
Confirmation of carrying out electrical and civil work/room renovation at installation site	Submitted

*[Signature]*  
Accounts Officer  
Accountant General Sindh  
Karachi.

*[Signature]*  
SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

*[Signature]*  
PROF. SHAMSHAD IMDAD KHAN  
Dentist  
Specialist Postgraduate Research Centre,  
Karachi

*[Signature]*  
DR. SYED AMIR RAZA  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017*

Confirmation of Three years free Service including spare parts from the date of installation.	Submitted
Guarantee letter that the quoted Machinery / Equipment is the original / meet required specification	Submitted
List of hospitals/Institutions where bidder have received work order for the same Manufacturer Mortuary Equipment and completed the supply and installation.	Not submitted
Proof for the availability of workshop & trained engineers on the pay role of bidder for after sale service and installation.	List of technical engineers and work shop are submitted.
Undertaking from Manufacturer that if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work.	Submitted
Remarks :	<b>RESPONSIVE</b>

*[Signature]*  
**Accounts Officer**  
Accountant General Sindh  
Karachi.

*[Signature]*  
**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT.  
GOVERNMENT OF SINDH

*[Signature]*

**PROF. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*[Signature]*  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17**

**Technical Bid opened on May 19, 2017**

**TECHNICAL EVALUATION**

<b>Item no: 01 COLD STORAGE CABINET FOR FOUR BODY</b>	<b>M/s. Medline Technologies (Pvt) Ltd</b>
Model of quoted equipment	KZM 40/450
Make of quoted equipment:	Kugel Medical
Country of origin: USA/UK/EEC/Japan	Germany
Refrigerated Body Storage (4 Body Capacity)	Yes
Cabinet height: 2230-2260mm	2300mm
Cabinet Depth: 2230-2260mm	2300mm
Cabinet Width: 950-1210mm	1250mm
1 bay, 4 tier with wide trays.	Yes
White finish, 100mm thick, high density rigid polyurethane insulation.	Yes
304 Stainless Steel, 0.8mm to internal & external surfaces.	Yes
Fully insulated floor structure, finished in 0.8-1mm thick stainless steel sheet.	Yes
Trays should be supported with free running, 50mm self-bearing acetyl stub rollers.	Yes
1 x 4 tier chill temperature bays for compatible wide for a full height door not less than 650mm width single full height door for single entry operation (3°C to +5°C)	Yes - Door height 2000mm Width : 680mm
4 No. 304 grade stainless steel not less than 600mm wide trays.	Yes- 620., SS. Trays
Internal structure should consist of stainless steel open racking for an even temperature throughout the store and easy access for cleaning.	Yes
High / low temperature alarm with volt free contact for connection to a BMS	Yes
Initial refrigerant charge.	Yes
Door should internally clad for crash protection.	Yes
1 No. rebated 'full height' insulated 100mm door with reinforced internal structure , size Not less than: 650 x 2000.	Yes
Door heater tapes to each full height door.	Yes
Door complete with "wipe clean" identity plate or drop in label holder.	Yes
Profiled fully magnetic p.v.c door gasket in rebate to fully protect the seal.	Yes
Lockable door latch.	Yes
Edge mount adjustable hinges should offer 180 deg. or more opening.	Yes
Leading edges should be provided to prevent damage to trolley rollers	Yes
Full width stainless steel carrying handles	Yes

Accounts Officer  
Accountant General (Sindh)  
Karachi.

SECTION OFFICER  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

DR. SHANWAZ MUDA KHAN  
Deputy Medical Superintendent  
Jinnah Postgraduate Hospital  
Karachi

DR. SYED AMIR RAZA  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017**

Roof mounted mono-block refrigeration system	Yes
3-5°C operating range in ambient of 32C to 50C .	Yes
R404a refrigerant, Auto defrost.	Yes
Digital control panel with temp display and visual alarms.	Yes
Turning mortuary cabinet light on/off	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 02 : - HYDRAULIC TROLLEY</u></b>	<b>M/s. Medline Technologies (Pvt.) Ltd</b>
Model of quoted equipment	HTW50/100
Make of quoted equipment:	Kugel Medical
Country of origin: USA/UK/EEC/Japan	Germany
Hydraulic mortuary trolley	Yes
Robustly construction, heavy duty, square section, welded steel tube.	Yes
Stable and versatile platform for easy to move.	Yes
Simple to use and built, to withstand continual and heavy use.	Yes
Full width, free running PVC coated rollers.	Yes
Finished in steel material.	Yes
4 No, 125mm braked castors, protective front bumpers	Yes
Reliable hydraulic system with dual action hydraulic hand pump or foot operated.	Yes
End handled with tray retaining mechanism.	Yes
Lift Height 300mm to 1650mm	320-1650mm
Dimensions: 650mm or more (W) x 2050mm or more (L) x 1050 or more (H) handle	2150mm(L) x 1650mm(H) 750mm(W)
Must be compatible with refrigeration cabinets.	Yes
Carrying weight 180kg or more.	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 03 : - COLD FOGGING MACHINE</u></b>	<b>M/s. Medline Technologies (Pvt.) Ltd</b>
Model of quoted equipment	Trijet 6208
Make of quoted equipment:	Fogmaster
Country of origin: USA/UK/EEC/Japan	USA

*(Signature)*  
Accounts Officer  
Accountant General Sindh,  
Karachi.

*(Signature)*  
SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

*(Signature)*  
PROF. SHAMSHAD KHAN  
Director  
District Hospital  
Jinnah Road  
Karachi

*(Signature)*  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.



***Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh For the year 2016-17***

**Technical Bid opened on May 19, 2017**

Rotatable fogging nozzles	Yes
Particle Size : 15-30 micron VMD, adjustable	Yes
Tank Capacity: 2 liters or more	Yes
Liquid Flow Rate: 0-250ml/min, adjustable	Yes
Should be cable to handles both oil and water-based chemical solutions	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 04 : - CEILING FAN</u></b>	<b>M/s. Medline Technologies (Pvt.) Ltd</b>
<b>Make:</b>	Pak fan – Pakistan brochure submitted
Size 56 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 05 : - EXHAUST FAN</u></b>	<b>M/s. Medline Technologies (Pvt.) Ltd</b>
<b>Make:</b>	Pak Fan-Pakistan brochure submitted
Size 18 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 06 : - STRETCHER WITH COVER</u></b>	<b>M/s. Medline Technologies (Pvt.) Ltd</b>
<b>Make:</b>	Strongman – Pakistan brochure submitted
Dead body transport stretcher	Yes
Complete with cover and straps	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 07 : -STAINLESS STEEL TABLE</u></b>	<b>M/s. Medline Technologies (Pvt.) Ltd .</b>
Model of quoted equipment	14301

*Accountant General Sindh*  
**Accounts Officer**  
 Accountant General Sindh  
 Karachi.

*Sullas*  
**SECTION OFFICER (PM&M)**  
 HEALTH DEPARTMENT  
 GOVERNMENT OF SINDH

*DR. SYED AMIR RAZA*  
**DR. SYED AMIR RAZA**  
 Deputy Medical Superintendent  
 SMBB Trauma Centre  
 Civil Hospital, Karachi.

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**For the year 2016-17**

**Technical Bid opened on May 19, 2017**

Make of quoted equipment:	Kugel Medical
Country of origin: USA/UK/EEC/Japan	Germany
304 stainless steel table	Yes
Dimensions: 2' (W) x 6.5' (L) x 4' (H)	520mm(W) x 2000mm(L) x 900mm(H)
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 08 : -REVOLVING CHAIR</u></b>	<b>M/s. Medline Technologies (Pvt) Ltd</b>
Make:	Local – brochure submitted
Rexene best Quality.	Yes
Seat and Back with cushion	Yes
Arms tilting and Hydraulic Base	Yes
Five Legs with 2 inch wheels	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 09 : -OFFICE TABLE</u></b>	<b>M/s. Medline Technologies (Pvt) Ltd</b>
Make:	Local – brochure submitted
Sheesham wood frame with lamination top with side rack. finished by spirit polish	Yes
with 3 draw Handle , locks , draw channel best quality	Yes
size Length 42inch Width 24 Height 26 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b><u>ITEM NO. 10 : -VISITING CHAIR</u></b>	<b>M/s. Medline Technologies (Pvt) Ltd</b>
Make:	Local – brochure submitted
Chair with arms, Seat & Seatback.	Yes
Minimum Dimensions : Width 20", Depth: 20", Height from seat: 18" (elegant design).	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
A	Submitted
<b>TRUNKY BASIS PROJECT:</b> Confirmation regarding installation and Commissioning of complete Package of Cold Storage Machinery / Equipment and Furniture Fixture including all accessories for Strengthening of Mortuary Facility at All Teaching & major Hospitals in Sindh with six months starting	

Accountant General  
Karachi.

SECTION D  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

suwas

PROF. SHAMIMZ MD  
M.B.B.S. (P) (M)  
Deptt. of Pathology  
State Medical Services  
Junah Postgraduate Hospital

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

	from date of establishing L/c.	
B	<b>MAINTENANCE WARRANTY</b> Confirmation of Maintenance of the machine/equipment during the whole period of warranty.	Submitted
C	<b>OEM CERTIFICATE</b> Manufacture (OEM) certificate of equipment Manufacturer confirmation certificate that the machine / equipment being used in the country of origin.	Submitted
D	<b>TRAINING:</b> Confirmation regarding Training for operation of the cold storage system	Submitted
E	<b>CIVIL AND ELECTRICAL WORK :</b> Confirmation for supply, installation, commissioning and Maintenance of complete Cold Storage for Mortuary including electrical and civil work/room renovation as per requirement of installation.	Submitted
<b>REMARKS FOR COMPLETE BID ON TURNKEY BASIS :</b>		<b>RESPONSIVE</b>

*[Signature]*  
**Accounts Officer**  
Accountant General Sindh  
Karachi.

*[Signature]*  
**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

*[Signature]*  
**DR. SHANNAZ IQBAL KEHAR**  
M.B.B.S., M.Phil (Path)  
Deptt. of Pathology  
Sindh Medical Services Institute,  
Jinnah Postgraduate Medical Centre,  
Karachi.

*[Signature]*  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment  
Strengthening of Mortuary facility at all Teaching & Major Hospitals  
For the year 2016-17  
Technical Bid opened on May 19, 2017*

**ANNEXURE VI**

*ture fixture for*

M/s. Universal Enterprises

Annexure-VI

**BID EVALUATION**

<b>Bid Evaluation Criteria</b>	<b>M/s. Universal Enterprises</b>
Bid is submitted as per SPP Rule 2010 (Amended 2013) clause 46(2) single stage two envelope bidding procedures.	Yes
Complete package/Turnkey solution	Yes
Original tender purchase receipt.	Yes
Photocopy of Bid security in shape of pay order.	Yes
Bid Validity : 90 days	Yes – as per tender
Compliance of tender terms and conditions, signed and stamped	Yes
Copy of Income Tax Certificate	Yes
Copy of GST Registration Certificate.	Yes
Copy of valid Professional Tax (Excise & Taxation) Certificate	Yes
Submission of Original catalogue of quoted items with technical bid from bidder.	Submitted brochure of Kugal Medical is mainly for Histopathology equipment. For the Morgue section, the information of refrigeration unit is mentioned but the information regarding cold storage cabinet is not mentioned.
Detail data sheet with essential technical and performance characteristics of the offered item on letter head of bidders.	Yes
Compliance of quality standard certificate	Submitted
Sole Agency certificate:	Authorization letter submitted, but not for Cold Storage.
Attestation of Sole Agent Certificate/distributorship letter from the concerned embassy.	NO.
Date of issuance of submitted sole agency certificate	May 11 <sup>th</sup> , 2017
Date of expiry of submitted sole agency certificate	NOT MENTIONED

**Accounts Officer**  
Accountant General Sindhi  
Karachi.

**SECTION OFFICER (PM&H)**  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**For the year 2016-17**

**Technical Bid opened on May 19, 2017**

Comments on the submitted sole agency certificate:	<p>The content of submitted authority letter says that it is issued for the projects in Sindh Province – Pakistan.</p> <p>The content do not refer that it is issued for Cold Storage Mortuary equipment and its allied accessories.</p> <p>The issuance of authorization letter is confirmed that the letter is issued for professional pathology equipment only.</p> <p>Two years validity of authorization letter is also not confirmed which was the essential requirement of tender.</p>
Original Equipment Manufacturer (OEM) certificate on the letter head of Manufacturer	Submitted- only for Professional Pathology equipment.
Certificate from the Manufacturer that the offered equipment is in used in the country of origin and also the international reference list.	Certificate is Not submitted, only reference list is attached.
Confirmation certificate on bidder's letter head regarding supply, installation, commissioning and Maintenance of Complete Cold Storage Mortuary System at installation sites.	Not submitted on letter head
Confirmation of post warranty Maintenance.	Not submitted
Confirmation of carrying out electrical and civil work/room renovation at installation site.	Not submitted
Confirmation of Three years free Service including spare parts from the date of installation.	Not submitted
Guarantee letter that the quoted Machinery / Equipment is the original / meet required specification	Not submitted
List of hospitals/Institutions where bidder have received work order for the same Manufacturer Mortuary Equipment and completed the supply and installation.	Not submitted
Proof for the availability of workshop & trained engineers on the pay role of bidder for after sale service and installation.	Submitted

Accounts Officer  
Accountant General  
Karachi.

*[Handwritten signature]*

*[Handwritten signature]*


SECTION OFFICER  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH

*[Handwritten signature]*  
PROF. SHAMIM UDDIN  
Deputy Medical Superintendent  
Sindh Provincial Hospital  
Karachi

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017*

<p>Undertaking from Manufacturer that if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work.</p>	<p>As per general and special condition of tender bidder has not provided an undertaking from Manufacturer i.e. <b>M/s. Kugal Medical-Germany</b>, that "if authorized distributor fails to carry out any assignment in total or in part the Manufacturer will be responsible to carry out the remaining work or complete work"</p>
<p>Remarks :</p>	<p><b>NON RESPONSIVE</b></p>

  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

  
**DR. SYED AMIR RAZA**  
M.B.S. (M. Pathology)  
Deptt. of Pathology  
Basic Medical Sciences Institute  
Jinnah Postgraduate Medical Centre  
(Karachi)

  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

  
**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh For the year 2016-17*

**Technical Bid opened on May 19, 2017**

**TECHNICAL EVALUATION**

<b>Item no: 01 COLD STORAGE CABINET FOR FOUR BODY</b>	<b>M/s. Universal Enterprises</b>
Model of quoted equipment	Sole agency certificate is not submitted and hence the technical evaluation is not carried out.
Make of quoted equipment:	
Country of origin: USA/UK/EEC/Japan	
Refrigerated Body Storage (4 Body Capacity)	
Cabinet height: 2230-2260mm	
Cabinet Depth: 2230-2260mm	
Cabinet Width: 950-1210mm	
1 bay, 4 tier with wide trays.	
White finish, 100mm thick, high density rigid polyurethane insulation.	
304 Stainless Steel, 0.8mm to internal & external surfaces.	
Fully insulated floor structure, finished in 0.8-1mm thick stainless steel sheet.	
Trays should be supported with free running, 50mm self-bearing acetyl stub rollers.	
1 x 4 tier chill temperature bays for compatible wide for a full height door not less than 650mm width single full height door for single entry operation (3°C to +5°C)	
4 No. 304 grade stainless steel not less than 600mm wide trays.	
Internal structure should consist of stainless steel open racking for an even temperature throughout the store and easy access for cleaning.	
High / low temperature alarm with volt free contact for connection to a BMS	
Initial refrigerant charge.	
Door should internally clad for crash protection.	
1 No. rebated 'full height' insulated 100mm door with reinforced internal structure , size Not less than: 650 x 2000.	
Door heater tapes to each full height door.	
Door complete with "wipe clean" identity plate or drop in label holder.	
Profiled fully magnetic p.v.c door gasket in rebate to fully protect the seal.	
Lockable door latch.	
Edge mount adjustable hinges should offer 180 deg or more opening.	
Leading edges should be provided to prevent damage to trolley rollers	
Full width stainless steel carrying handles	
Roof mounted mono-block refrigeration system	

*Amir*  
**Accounts Officer**  
 Accountant General Sindh,  
 Karachi.

*Sulias*  
 PROF. SHAHMAD IMRAN KHAN  
 M.B.F.S., M.C.P., M.P.S.P.  
 Director of Pathology, Bacteriology,  
 Serology, Parasitology and  
 Jinnah Postgraduate and Medical  
 Centre.

**DR. SYED AMIR RAZA**  
 Deputy Medical Superintendent  
 SMBB Trauma Centre  
 Civil Hospital, Karachi.

*[Signature]*  
**SECTION OFFICER (PM&I)**  
 Page 38 of 42  
 HEALTH DEPARTMENT,  
 GOVERNMENT OF SINDH

*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17  
Technical Bid opened on May 19, 2017*

3-5°C operating range in ambient of 32C to 50C .	
R404a refrigerant, Auto defrost.	
Digital control panel with temp display and visual alarms.	
Turning mortuary cabinet light on/off	
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 02 : - HYDRAULIC TROLLEY</b>	<b>M/s. Universal Enterprises</b>
Model of quoted equipment	
Make of quoted equipment:	
Country of origin: USA/UK/EEC/Japan	
Hydraulic mortuary trolley	
Robustly construction, heavy duty, square section, welded steel tube.	
Stable and versatile platform for easy to move.	
Simple to use and built, to withstand continual and heavy use.	
Full width, free running PVC coated rollers.	
Finished in steel material.	
4 No, 125mm braked castors, protective front bumpers	
Reliable hydraulic system with dual action hydraulic hand pump or foot operated.	
End handled with tray retaining mechanism.	
Lift Height 300mm to 1650mm	
Dimensions: 650mm or more (W) x 2050mm or more (L) x 1050 or more (H) handle	
Must be compatible with refrigeration cabinets.	
Carrying weight 180kg or more.	
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 03 : - COLD FOGGING MACHINE</b>	<b>M/s. Universal Enterprises</b>
Model of quoted equipment	Not mentioned
Make of quoted equipment:	Fogmaster
Country of origin: USA/UK/EEC/Japan	Brochure not attached
Rotatable fogging nozzles	
Particle Size : 15-30 micron VMD, adjustable	
Tank Capacity: 2 liters or more	
	Sole agency certificate and brochure are not submitted and hence the technical evaluation is not carried

*Accounts Officer*  
Accountant General Sindh,  
Karachi.

*DR. SYED AMIR RAZA*  
Deputy Medical Superintendent  
SMBB Trauma Centre  
ital, Karachi.

*DR. SYED AMIR RAZA*  
Deputy Medical Superintendent  
SMBB Trauma Centre  
ital, Karachi.

Page 39 of 42  
SECTION OFFICER (PM&I)  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH



*Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for  
Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh  
For the year 2016-17*

**Technical Bid opened on May 19, 2017**

Liquid Flow Rate: 0-250ml/min, adjustable	out.
Should be cable to handles both oil and water-based chemical solutions	
<b>REMARKS</b>	<b>NON RESPONSIVE</b>
<b>ITEM NO. 04 : - CEILING FAN</b>	<b>M/s. Universal Enterprises</b>
Make:	Pak fan – Pakistan Brochure not submitted
Size 56 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 05 : - EXHAUST FAN</b>	<b>M/s. Universal Enterprises</b>
Make:	Pak fan – Pakistan Brochure not submitted
Size 18 inch	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 06 : - STRETCHER WITH COVER</b>	<b>M/s. Universal Enterprises</b>
Make:	Pakistan Brochure not submitted
Dead body transport stretcher	Yes
Complete with cover and straps	Yes
<b>REMARKS</b>	<b>RESPONSIVE</b>
<b>ITEM NO. 07 : -STAINLESS STEEL TABLE</b>	<b>M/s. Universal Enterprises</b>
Model of quoted equipment	Sole agency certificate is not submitted and hence the technical evaluation is not carried out.
Make of quoted equipment:	
Country of origin: USA/UK/EEC/Japan	
304 stainless steel table	
Dimensions: 2' (W) x 0.5' (L) x 4' (H)	
<b>REMARKS</b>	<b>NON RESPONSIVE</b>

*Accounts Officer*  
**Accounts Officer**  
Accountant General Sindh,  
Karachi.

*Sawas*

**PROF. SHAMSHAD KHAN**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Hospital, Karachi.

**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Hospital, Karachi.

**SECTION OFFICER (PM&I)**  
HEALTH DEPARTMENT,  
GOVERNMENT OF SINDH

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**For the year 2016-17**

**Technical Bid opened on May 19, 2017**

<b>ITEM NO. 08 : -REVOLVING CHAIR</b>		<b>M/s. Universal Enterprises</b>
Make:		Pakistan
		Brochure not submitted
Rexene best Quality.		Yes
Seat and Back with cushion		Yes
Arms tilting and Hydraulic Base		Yes
Five Legs with 2 inch wheels		Yes
<b>REMARKS</b>		<b>RESPONSIVE</b>
<b>ITEM NO. 09 : -OFFICE TABLE</b>		<b>M/s. Universal Enterprises</b>
Make:		Local
		Brochure not submitted
Sheesham wood frame with lamination top with side rack, finished by spirit polish		Yes
with 3 draw Handle , locks , draw channel best quality		Yes
size Length 42inch Width 24 Height 26 inch		Yes
<b>REMARKS</b>		<b>RESPONSIVE</b>
<b>ITEM NO. 10 : -VISITING CHAIR</b>		<b>M/s. Universal Enterprises</b>
Make:		Pakistan
		Brochure not submitted
Chair with arms, Seat & Seatback.		Yes
Minimum Dimensions : Width 20", Depth: 20", Height from seat: 18" (elegant design).		Yes
<b>REMARKS</b>		<b>RESPONSIVE</b>
A	<b>TRUNKY BASIS PROJECT:</b> Confirmation regarding installation and Commissioning of complete Package of Cold Storage Machinery / Equipment and Furniture Fixture including all accessories for Strengthening of Mortuary Facility at All Teaching & major Hospitals in Sindh with six months starting from date of establishing L/c.	Not submitted
B	<b>MAINTENANCE WARRANTY</b> Confirmation of Maintenance of the machine/equipment during the whole period of warranty.	Not submitted

*Tamir*  
**Accounts Officer**  
Accountant General Sindh,  
K. S. S. S.

*Sulias*  
**DR. SHANNOZ IMRAN KEHAR**  
M.S.B.S. (M. Phil. (Ed))  
Deputy of the  
State Medical & Health Officer  
Jinnah Postgraduate Medical Centre,  
Karachi

*Amir Raza*  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*SA*  
**SECTION OFFICER (PMS)**  
HEALTH DEPARTMENT  
GOVERNMENT OF SINDH  
Page 41 of 42

**Tender for provision, installation and commissioning of Cold storages, Machinery / Equipment and furniture fixture for Strengthening of Mortuary facility at all Teaching & Major Hospitals in Sindh**

**For the year 2016-17**

**Technical Bid opened on May 19, 2017**

C	<b>OEM CERTIFICATE</b> Manufacture (OEM) certificate of equipment Manufacturer confirmation certificate that the machine / equipment being used in the country of origin.	Not submitted
D	<b>TRAINING:</b> Confirmation regarding Training for operation of the cold storage system	Not submitted
E	<b>CIVIL AND ELECTRICAL WORK :</b> Confirmation for supply, installation, commissioning and Maintenance of complete Cold Storage for Mortuary including electrical and civil work/room renovation as per requirement of installation.	Not submitted
<b>REMARKS FOR COMPLETE BID ON TURNKEY BASIS :</b>		<b>NON-RESPONSIVE</b>

*[Signature]*  
**Accounts Officer**  
**Accountant General Sindh,**  
**Karachi.**

*[Signature]*  
**DR. SHANNAZ IMDAD KHAN**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*[Signature]*  
**DR. SYED AMIR RAZA**  
Deputy Medical Superintendent  
SMBB Trauma Centre  
Civil Hospital, Karachi.

*[Signature]*  
**SECTION OFFICER (PM&I)**  
**HEALTH DEPARTMENT,**  
**GOVERNMENT OF SINDH**