



KARACHI WATER & SEWERAGE BOARD

OFFICE OF THE DIRECTOR (DESIGN & ESTIMATE)

BID EVALUATION REPORT


1	Name of Procuring Agency :	KARACHI WATER & SEWERAGE BOARD
2	Tender Reference No:	SPPRA Serial No.34568 I.D No._____
3	Tender Description/Name of Work/Item:	REPAIRING / MAINTENANCE OF 1250 KVA HT "STEP DOWN" TRANSFORMER AEG MODEL 1957 AT POWER HOUSE AT STP-II MEHMOODABAD
4	Method of Procurement:	<u>Single Stage (One Envelop)</u>
5	Tender Published:	<u>Through SPPRA Web Site</u>
6	Total Bid Documents Sold:	<u>2 Nos</u>
7	Total Bid Received:	<u>2 Nos</u>
8	Technical Bid Opening Date (if applicable):	<u>N/A</u>
9	No. of Bid Technically Qualified (if applicable)	<u>N/A</u>
10	Bid (s) Rejected:	<u>NIL</u>
11	Financial Bid Opening Date:	19-10-2017


12 BID EVALUATION REPORT


S #	Name of Firm / Bidder	COST OFFERED BY THE BIDDER	RANKING IN TERMS OF COST	COMPARIS ON WITH ESTIMATED COST	REASON FOR ACCEPTANCE / REJECTION	REMARKS
1.	M/s.Malik & Co.	Rs.9,99,961/-	1 st Lowest	@9.374% Above	Pay order and other required documents are available. P.O # 19018060 dt:19-10-2017 Rs.20,000/-from HBL Malir Cantt Branch Karachi	Substantially Responsive
2	M/s.Kashif Engineering Works	Rs.14,73,261/-	2 nd Lowest	@61.142% Above	Pay order and other required documents are available. Bank Guarantee # 845/MC/22/2017 dt: 18-10-2017 Rs.30,000/-from UBL Model Colony Branch Karachi	Substantially Responsive


The all concerned bidders are being informed accordingly.

The E.E Concerned for compliance of Rule-45 of SPPRA 2010 **M/s.Malik & Co.** declared as the lowest responsive bidder by the Committee and recommended for sanction from Competent Authority.


(Khuwaja Muhammad Ahmed)
A.O (E&M-Sew)
Member / Secretary


(Saif-ul-Haque)
Additional Director Internal
Audit – KMC Member


(Maqsood Ahmed Shaikh)
Superintending Engineer (KMC)
Member


(Manzoor Ali Khatri)
S.E (TP's Circle)
Members


(Saleem Ahmed)
Director (Design & Estimate)
Convener

NIT Sr. No. SPPRA Serial No.34568

Method of Procurement: Single Stage Single Envelope.

Name of Work: REPAIRING / MAINTENANCE OF 1250 KVA HT "STEP DOWN" TRANSFORMER AEG MODEL 1957 AT POWER HOUSE AT STP-II MEHMOODABAD

MINUTES OF BID OPENING MEETING.

A meeting of the procurement committee of this department was held on 19-10-2017 for opening the bids received in respect of subject NIT till deadlines of submission. The meeting was attended by all / following members of the procurement committee and the representative of bidders.


(Attendance sheet is enclosed).

2. Two bidders submitted their bids till the deadline of submission.
 - i. M/s. Malik & Co.
 - ii. M/s. Kashif Engineering Works
3. The bids were opened at 2:30 P.M in the presence of the above mentioned participants and the rates quoted by bidders were read aloud and encircled by Chairman of the Procurement Committee.


S. No	Name of Firm	Quoted Price	Amount of Bid Security	Pay Order No. / Date
1.	M/s.Malik & Co.	Rs.9,99,960/-	Rs.20,000/-	P.O # 19018060 dt:19-10-2017 from HBL Malir Cantt Branch Karachi
2.	M/s.Kashif Engineering Works	Rs.14,73,261/-	Rs.30,000/-	Bank Guarantee # 845/MC/22/2017 dt: 18-10-2017 from UBL Model Colony Branch Karachi


4. The one bid contain overwriting duly signed.
5. The committee shall examine all the bids as per the qualification / eligibility criteria provided in the bidding document and verify the documents and bid security submitted by the bidders (if required).

The meeting ended with the vote of thanks to and from the chair.


(Khurwaja Muhammad Ahmed)
A.O (E&M-Sew)
Member / Secretary


(Saif-ul-Haque)
Additional Director Internal
Audit – KMC Member


(Maqsood Ahmed Shaikh)
Superintending Engineer (KMC)
Member


(Manzoor Ali Khatri)
S.E (TP's Circle)
Members


(Saleem Ahmed)
Director (Design & Estimate)
Convener

Method and procedure of procurement: Open Competitive Bidding (National/ International Competitive Bidding) (Single Stage–One Envelope)


Description of work: REPAIRING / MAINTENANCE OF 1250 KVA HT "STEP DOWN" TRANSFORMER AEG MODEL 1957 AT POWER HOUSE AT STP-II MEHMOODABAD

Date of Opening: 19-10-2017


BIDDERS' ELIGIBILITY/ QUALIFICATION REPORT


Eligibility/ Qualification Criteria:

S. No.	Eligibility / Qualification Criteria	Bidders' Name	
		M/s.Malik & Co.	M/s.Kashif Engineering Works
1.	Registration with PEC (if applicable)	N/A	N/A
2.	NTN	Yes	Yes
3.	Sales Tax Registration	N/A	N/A
4.	Registration with Sindh Revenue Board (SRB)	Yes	Yes
	Qualification Criteria:		
5.	Minimum three years' experience of relevant field.	Yes	Yes
6.	Turnover of at least last three years	Yes	Yes
7.	Required Bid Security is attached.	Yes	Yes
8.	Bid is signed, named and stamped by the authorized person of the firm along with Authorization letter.	Yes	Yes
9.	Any other factor deemed to be relevant by the procuring agency subject to provision of Rule-44	N/A	N/A
10.	Qualified/ disqualified	Qualified	Qualified


(Khwaja Muhammad Ahmed)
A.O (E&M-Sew)
Member / Secretary


(Saif-ul-Haque)
Additional Director Internal
Audit – KMC Member


(Maqsood Ahmed Shaikh)
Superintending Engineer (KMC)
Member


(Manzoor Ali Khatri)
S.E (TP's Circle)
Members


(Saleem Ahmed)
19/10/17
Director (Design & Estimate)
Convener


COMPARATIVE STATEMENT

Name of Work: REPAIRING / MAINTENANCE OF 1250 KVA HT "STEP DOWN" TRANSFORMER AEG MODEL 1957 AT POWER HOUSE AT STP-II MEHMOODABAD

Item No	Description of Work	Estimated Cost				M/s.Malik & Co.		M/s.Kashif Engineering Works		
		Quantity	Rate	Per	Amount	Rate	Amount	Rate	Amount	
1	Dismantling of 1250 KVA H.T "Step Town" Transformer AEG model 1957 and having weight 4.64 tons for repairing / maintenance / removing shortage of field winding including repalcing of all damges, burnt, parts, copper, strip, winding insulators, rings, intenral wiring, bypass switch, regulating electronic in put, and out condit entires and right, left lower side panels etc complete ina llr espects and site requirement. and set Voltage (1) 11625V 440 Volts (2) 11000V 440 Volts (3) 10175V 380 Volts Dismantling / Refitting / Re-mounting to connect the H.T system. Cartage of long boom mobile Crane included in this Item rate are current market L/S.	1.00	Job	646,600	P/Job	646,600.00	700,000	700,000.00	1,000,000	1,000,000.00
2	Repairing / maintenance of 11 KVA Spout trolley Repairing, replacing of burnt bus bar, copper nuts and bolts springs, including alignment of handle and guides of trollys are complete in all respect as required.	1.00	Job	93,200	P/Job	93,200.00	100,000	100,000.00	200,000	200,000.00


**Name of Work: REPAIRING / MAINTENANCE OF 1250 KVA HT "STEP DOWN" TRANSFORMER AEG MODEL 1957 AT POWER HOUSE
AT STP-II MEHMOODABAD**

Item No	Description of Work	Estimated Cost				M/s.Malik & Co.		M/s.Kashif Engineering Works		
		Quantity	Rate	Per	Amount	Rate	Amount	Rate	Amount	
3	Excavation for pipe line in trenches and pits in all kind of soil of murum i/c trimming and dressing sides to true alignment and shape leveling of beds of trenches to correct level and grade cutting joints holes and disposal of surplus earth within one chain as directed by Engineer Incharge providing fence guards, lights, flags sand temporary crossing for non-vehicular traffic wherever required lift upto 5 ft (1.52 m) and lead upto one chain (30.5m). 45'x2'x5'	450.00	Cft	4650.00	%0Cft	2,092.50	4650.00	2,092.50	4650.00	2,092.50
4	Making cable joints for 400 mm ² H.T PVC armored 03 Core cable i/c P/F all accessories required for cable jointing insulation cores, Fay rolls etc complete in all respect and site requirements, as per direction of Engineer Incharge.	4.00	Nos	25,000	Each	100,000.00	30,000	120,000.00	50,000	200,000.00
5	Refilling the excavated stuff in trenches 6" thick layer i/c watering ramming to full compaction etc complete.	423.50	Cft	2760.00	%0Cft	1,168.86	2050.00	868.18	2760.00	1,168.86
6	Repairing / Maintenance of L.T panel Repairing, replacing of burnt bus bars, copper nuts and bolts, including CT, switches etc complete in all as required.	1.00	Job	71,200	P/Job	71,200.00	77,000	77,000.00	70,000	70,000.00
TOTAL QUOTED / CORRECTED COST						914,261		999,961		1,473,261


(Khawaja Muhammad Ahmed)
Accounts Officer (E&M-Sew)
Member / Secretary


(Saif-ul-Haque)
Additional Director Internal
Audit – KMC Member


(Maqsood Ahmed Shaikh)
Superintending Engineer (KMC)
Member


(Manzoor Ali Khatri)
S.E (TP's Cicle)
Member


(Saleem Ahmed)
Director (Design & Estimate)
Convener

ESTIMATE

NAME OF WORK: REPAIR / MAINTENANCE OF 1250 KVA HT "STEP DOWN" TRANSFORMER AEG MODEL 1957 AT POWER HOUSE AT STP-II MEHMOODABAD KW&SB.

S. #	Description of Work	Qty	Rate Rs	Per	Total (Rs)
1	Dismantling of 1250 KVA H.T "Step Down" Transformer AEG model 1957 and having weight 4.64 tons for repairing / maintenance / removing shortage of field winding including replacing of all damages. burnt, parts, copper, strips, winding insulators, rings, internal wiring, bypass switch, regulating electronic in put, and out conduit entires and right, left lower side panels etc, complete in all respects and site requirement, and set Voltage.(1) 11625V.....440 Volts (2) 11000 V 400 Volts (3) 10175 V 380 Volts Dismantling / Refitting / Re-mounting to connect the H.T system. Cartage of long boom mobile Crane included in this Item Rate are current market L/S.	01 Job	646600/- 722,000/-	Job	646,600 722,000.00
2	Repairing / maintenance of 11 KVA Spout trolley Repairing. Replacing of burnt bus bar, copper nuts and bolts springs, including alignment of handle and guides of trolley etc complete in all respect as required.	01 Job	93200/- 95,000/-	Job	93200 - 95,000.00
3	Excavation for pipe line in trenches and pits in all kinds of soil of murum i/c trimming and dressing sides alignment and shape leveling of beds of trench to correct level and grade cutting jointing holes and disposal of surplus earth within a one chain as directed by Engineer In charge providing fence guards, light flags and temporary crossing for non vehicular traffic where ever required lift upto 5'ft. (1.52.m) and lead upto one chain (30.5m). 45' x 2' x 5'.	450 Cft	4,650/=	% 0 Cft	2092.50
4	Making cable joints for 400 mm ² HT PVC armored 03 core cable i/c P/F all accessories required for cable jointing insulation cores, Fay rolls etc complete in all respects and site requirements, as per direction of Engineer In-charge.	04 Nos	25,000/=	No	1,00,000.00
5	Refilling the Excavated stuff in trenches 6" inches thick layer i/c watering, ramming to full compaction etc. complete.	423.5 Cft	2,760/=	% 0 Cft	1169.00
6	Repairing / Maintenance of I.T panel Repairing. Replacing of burnt bus bars, copper nuts and bolts, including CT, switches etc. complete in all asrequired	01 Job	71200/- 75,000/-	Job	71200 - 75,000.00

Total Amount (Rs.) 9,95,262/-
9,14,261/-

Prepared by: ABDULLAH MADDICH
Assistant Executive Engineer
(STP-II) KW & SB

[Signature]
Executive Engineer
STP-II, KW&SB

Estimate Tech. checked & Sanctioned for No. 9,14,261/-

An estimate amounting to Rs. 995262/- has been prepared by the concerned division. After checking the rates and calculation of the estimate it comes to Rs. 9,14,261/- (Rupees Nine Lacs, Fourteen thousand two hundred & Sixty one only), vide letter No. KW&SB/DESIGN/DIR/2011/722 dt 29-8-2012.

[Signature]
Executive Engineer
STP-II, KW&SB