


BID EVALUATION REPORT


01. Name of Procuring Agency: Underground Coal Gasification Project, Tharparkar.
02. Tender Reference No: Elect-224 (R-2)/2015
03. Tender Description/Name of Work/Item: Tender for "Supply of Dummy Panel"
04. Method of Procurement: Limited Tender below Rupees One Million.
05. Tender Published: SPPRA Web Site Sr. 22636
Print & Electronic Media (SPPRA ID No & Newspapers names with dates)
06. Total Bid documents Sold: 02 (Two)
07. Total Bid documents Received: 02 (Two)
08. Technical Bid Opening date: (if applicable) N/A (Provide detail in separate form)
09. No of Bid technically qualified (if applicable) N/A
10. Bid (s) Rejected: Nil
11. Financial Bid Opening Date: 24.02.15


12. Bid Evaluation Report:

S. No	Name of Firm or Bidder	Cost Offered by the Bidder In Pak Rs.	Ranking in terms of Cost	Comparison with estimated cost	Reasons for acceptance/ rejection	Remarks
01	M/s Jagani & Brothers Mithi.	982,800/-	1 st Lowest	Nearest to the estimated cost.	Accepted as a 1 st Lowest	Work Order may be approved/ issued after hoisting on SPPRA website having total Cost Rs. 982,800/-
02	M/s Britlite Engineering Company Karachi	1,123,200/-	2 nd Lowest	Above to the estimated cost	Accepted as a 2 nd Lowest	

Tender Opening Committee


Jahanzeb Khan Abro
Engineer Electrical


Muhammad Tarique
Asst. Director (SCA Mithi)


Muhammad Imran Jarral
SS (Chemistry)




MINUTES OF THE TENDER OPENING
TENDER # UCG/ELECT-224(R-2)/2015
"SUPPLY OF DUMMY PANEL"


The Underground Coal Gasification Thar Project, Energy Department, Government of Sindh, invited sealed tender from reputed suppliers / firms registered with income tax/sales tax department for "Supply of Dummy Panel" through limited tender Nq. UCG/Elect-224(R-2)/2015 hoisted at SPPRA Website vide Sr. #22636 dated 4th February, 2015.

2. The tender documents were purchased by Two suppliers / firms as per detail given below: -
 - a) M/s Jagani & Brothers Mithi
 - b) M/s Britlite Engineering Company Karachi.
3. Following suppliers / firms submitted their tender documents / bids one hour before opening time i.e. on 24th February 2015 at 1100 hours : -
 - a) M/s Jagani & Brothers Mithi.
 - b) M/s Britlite Engineering Company Karachi.
4. The Bids submitted by the firms were opened publicly on 24th February 2015 at 1200 Hours in the presence of the Procurement Committee and the participant bidder M/s Jagani & Brothers Mithi. M/s Britlite Engineering Company Karachi did not participate in the Tender Opening (Attendance Sheet is attached). The evaluation of the bids was carried out in the light of Eligibility Criteria, Specifications and Conditions laid down in the Tender Documents as under:
 - a) **M/s Jagani & Brothers Mithi**

M/s Jagani & Brothers Mithi has submitted complete bid along with all necessary documents and quoted all items of the tender. As per price comparison (CST) M/s Jagani & Brothers Mithi has submitted the lowest bid.
 - b) **M/s Britlite Engineering Company Karachi.**

M/s Britlite Engineering Company Karachi has submitted all necessary documents, however quoted the rates of all the items. As per comparison (CST) the prices of quoted above to the estimated cost higher than the lowest bidder. Hence the bid is 2nd lowest.
5. In view of the evaluation M/s Jagani & Brothers Mithi, being the lowest bidder, may be awarded the tender, after seven days of hoisting BER at SPPRA website.


(Jaharzeb Khan Abro)
Engineer (Electrical)
UCG Project Thar
Member


(Muhammad Imran Jarral)
SS (Chemistry)
UCG Project Thar
President


(Muhammad Tarique)
Representative of Incharge Site
Sindh Coal Authority, Mithi
Member

COMPARATIVE STATEMENT

Tender No. UCCG/Elect-224(R-2)/15
Tender Opening Date is 24.02.2015

S. No	Description	Unit	Qty Req	M/s Jagani & Brothers Mithi		M/s Britlite Engineering Company Karachi	
				Unit Price	Total Price	Unit Price	Total Price
1	Supply, installation and commissioning of Dummy panel coupled with existing panel, DWG copy is attached, floor standing, Front access type L.V (400 Volts AC, 50Hz, TPNE) made of 2mmMS sheet, Upper and Down Plate Detachable and by using with proper glands completed in all respects with weather coated, having 3P, Neutral and Earth busbars, comprising of: Current Rating Capacity 4000 Amp, Copper bus bars with weight 8.89KG/m, Material E-CU-F25 or equivalent, ambient temperature 35°C, max permissible temperature of the busbars 65°C, Size 100x10mm, 3 nos of painted Bus bar on each phase (R, Y, B). Neutral 1x100x10mm, Earthing busbar 60mm x 10mm.	Nos	1	840,000	840,000	960,000	960,000
	Total				840,000		960,000
					142,800		163,200
	G.Total				982,800		1,123,200

Remarks: M/s Jagani & Brothers Mithi, is the lowest.


Jaganzeb Khan Abro
Engineer (Electrical)
UCCG Thar


Muhammad Tariq
Assistant Director (SCA Mithi)


Muhammad Imran Jarral
SS (Chemistry)
UCCG Thar