



No.UCG/Elect-54/12

September 17, 2012

Subject: Tender for Control & Power Spares for HP Compressors.

Detail specifications of the subject items are as under:-

S. No.	Tender Specification	Unit	Qty	Unit Price	Total Price
01.	<b><u>3-POLE MAGNETIC CONTACTOR</u></b>  3 Pole magnetic contactor with auxiliary contacts (2NO& 2NC), Coil Voltage: 400V, Current: 225A , 110KW Ref: Siemens [Type: 3RT10 64, Size Type: S10 (3RT1.6)], Schneider, ABB, LS	No	02		
02	<b><u>3-POLE MAGNETIC CONTACTOR</u></b>  3 Pole magnetic contactor with auxiliary contacts (2NO& 2NC), Coil Voltage: 400V, Current: 150A , 75KW Ref: Siemens [Type: 3RT10 55, Size Type: S6 (3RT1.5)], Schneider, ABB, LS	No	01		
03	<b><u>SOLID STATE OVER LOAD RELAY</u></b>  Solid State Overload Relay, Current Range: (55~250) A, Coil Voltage: 400V, Ref: Siemens [Type: 3RB10 66,Class 10], Schneider, ABB, LS	No	02		
04	<b><u>TIMER</u></b>  Timer Coil Voltage: 400V 2NO & 2NC Contacts , Range (0~30)sec Make: (Siemens, ABB, Schneider, Panasonic)	No	02		
05	<b><u>Motor</u></b>  Motor Type: YS 7124 IP44 Voltage: 380 VAC Current: 1.12A Wattage: 370 RPM: 1400 , 50 Hz Make: WS	No	02		

06.	<b>Indication Lamps:</b> Type:SAD16-22D/S32 Voltage:380V, Green LED,Qty:6 Type:SAD16-22D/S32 Voltage:380V, Yellow LED,Qty:3 Type:AD16-22D/S31 Voltage:220V, Red LED,Qty:3≤20mA (22mm Internal Dia)	No	12		
07	<b>TEMPERATURE CONTROLLER:</b> Temperature Range: (0~400 °C), AC: 220V, ON/OFF Relay Output, Size (6.5mm,6.5mm) Make (NUX HANYONG, Equivalent) Suitable for K Type Thermocouple	No	02		
08	<b>LOADING / UNLOADING SWITCH:</b> Make: TELEMECHANIQUE Type: XMLB070D2S11 NAUTILUS Voltage (Ue): 240VAC 1.5 A IP 66 Voltage (Ui): 500VAC Range Plage: (700-7000) Differential E card: (5000-470)	No	02		

- a. Blank tender forms can be collected from the office of Manager (Admin & Accounts), UCG Project Thar, upto 04-10-2012 at 12:00 Noon, during office hours after depositing the tender fee amounting to Rs.200/- (Non Refundable) in the shape of pay order in favor of Accounts Officer, UCG Thar Project, Islamkot.
- b. The tenders will be received backup to 05-10-2012 at 11:00 and will be opened on the same day at 12:00hrs in the presence of Purchase Committee and the bidders or their authorized representatives who wish to be present.
- c. Bid Security amounting to 2% of Bid Price should be submitted along with the Bid in shape of Pay Order in favor of Accounts Officer, UCG Thar Project, issued by any scheduled Bank of Pakistan.
- d. The bid security will be forfeited to the Government, if the bidder withdraws his bid after opening and before the expiry of the bid validity period or fails to sign the contract if the bid is accepted.
- e. The validity period of quotations must be 90 days.
- f. Amount of the tender is below Rs.01 Million.
- g. Conditional tender and tender without bid security shall not be considered.

- h. Delivery time will be 10 days starting after the issuance of supply order.
- i. GST/Income Tax Certificates, as the case may be, must be accompanied with the tender. The procuring agency may reject all or any bid at any time prior to the acceptance of a bid or proposal, subject to the relevant provision of SPP Rules 2010.
- j. Tender envelope should bear the tender No. UCG/ Elect-54/12 **and Tender for Control & Power Spares for HP Compressors.**

**Assistant Manager (Admin)**

UCG Thar Project Site,  
C/O Manager,  
National Bank of Pakistan  
Islamkot.  
Ph: 0232-923036