



No.UCG/Cham-63/12

October 09, 2012

Subject: **Tender for Air Dryer, Heatless Regenerative Type.**

Detail specifications of the subject items are as under:-

Air Dryer and related accessories are required at Instrument Air Line for smooth running of controllers. The Dryer is to be installed in open field at UCG site where ambient temperature is 50°C.

SPECIFICATION:

Capacity	3.0 – 5.0 NM ³ /Min
Working Pressure	4.0 – 10.0 Bar
Inlet Temperature	0- 45°C
Dew Point	-40°C
Regenerative Type	Heatless
Operating Cycle	10 Minutes
Pre & Post Filters	Yes
Quantity	01 Set

Note: Only Manufacturers and authorized dealers having market repute can participate. European/Korea/Taiwan Origin will be preferred. The successful bidder should supply, install and commission these equipments at UCG Site Islamkot along with one year warranty.

- Blank tender forms can be collected from the office of Manager (Admin & Accounts), UCG Project Thar, upto 23-10-2012 after depositing the tender fee amounting to Rs.200/- (Non Refundable) in the shape of pay order in favor of Accounts Officer, UCG Thar Project, Islamkot.
- The tenders will be received backup to 23-10-2012 at 11:00 and will be opened on the same day at 12:00hrs in the presence of Purchase Committee and the bidders or their authorized representatives who wish to be present.
- Bid Security amounting to 2% of Bid Price should be submitted along with the Bid in shape of Pay Order in favor of Accounts Officer, UCG Thar Project, issued by any scheduled Bank of Pakistan.
- The bid security will be forfeited to the Government, if the bidder withdraws his bid after opening and before the expiry of the bid validity period or fails to sign the contract if the bid is accepted.

- f. Amount of the tender is below Rs.01 Million.
- g. Delivery time at UCG Site will be 10-15 days starting after the issuance of supply order.
- h. Conditional tender and tender without bid security shall not be considered.
- i. GST/Income Tax Certificates, as the case may be, must be accompanied with the tender. The procuring agency may reject all or any bid at any time prior to the acceptance of a bid or proposal, subject to the relevant provision of SPP Rules 2010.
- j. Tender envelope should bear the tender No. UCG/ Cham-63/12 **and Tender for Air Dryer, Heatless Regenerative Type**

Assistant Manager (Admin)
UCG Thar Project Site,
C/O Manager,
National Bank of Pakistan
Islamkot.
Ph: 0232-923036