



UCG/Tender/Mech-72/2013

March 19, 2013

Subject: **Tender for H.P & Feed Pumps**

UCG Thar Project is interested in the purchase of:-

S. No	Description	Qty
01.	<p><u>Water Pumps (Centrifugal Type)</u></p> <p>a) Flow (Minimum): 500 Ltr/Mint b) The working pressure must be 3-4 bars at full opening of discharge valve. c) Suction 2½" and Discharge 2½" d) 3-Phase, 380V-400V, f-50Hz, IP=65 e) Service factor S1 (Continuous duty) f) Make USA, Japan or any European country Or Equivalent to Grundfos Model No. CR-32-5-15HP Or Grundfos Model No. CR-32-6-20HP</p> <p>g) Pump may be RF type.</p> <p>h) Installation and commissioning of pumps at UCG Site Islamkot included in the quotation.</p> <p>The quotation may also include list of operational spare parts alongwith price for three years.</p>	02
02.	<p><u>R. O. Plant Pumps</u></p> <p>A:</p> <p>a) Rated Flow: 40-50 GPM b) Rated Head: 100ft c) Impellers: 04 d) Stages: 04 e) Pump housing: Stainless steel Impeller: Stainless steel</p> <p><u>Electrical Data</u></p> <p>f) Rated Power :02HP g) Rated Voltage: 1x220-230/240 h) Rated Speed:2700 rpm i) Enclosure Class: IP-55.</p>	01

	<p>j) Insulation class : F</p> <p>k) Make USA, Japan or any European Or Equivalent to Grundfos CRN 10-4 A-P-G-E-HQQE</p> <p>l) Pump may be RF type</p> <p>m) Installation and commissioning of pumps at UCG Site Islamkot included in the quotation.</p> <p>n) The quotation may also include list of operational spare parts alongwith price for three years.</p>	
03	<p>B-</p> <p>a. Rated Flow: 40-50 GPM</p> <p>b. Rated Head: 300ft</p> <p>c. Impellers: 12</p> <p>d. Stages: 12</p> <p>e. Pump housing: Stainless steel ASTM A 351 CF 8M</p> <p>f. Impeller: Stainless steel AISI 316</p> <p>Electrical Data</p> <p>g. Rated Power :02HP</p> <p>h. Rated Voltage: 220-240/380-415</p> <p>i. Rated Speed:2900 rpm</p> <p>j. Enclosure Class: IP-55.</p> <p>k. Insulation class : F</p> <p>l. Make USA, Japan or any European Or Equivalent to Grundfos CRN 10-12 A-P-G-E-HQQE</p> <p>m. Pump may be RF type</p> <p>n. Installation and commissioning of pumps at UCG Site Islamkot included in the quotation.</p> <p>o. The quotation may also include list of operational spare parts alongwith price for three years.</p>	01

- 1) Blank tender forms can be collected from the office of Manager (Admin & Accounts), UCG Project Thar, upto 10.04-2013 at 1500 Noon, during office hours after depositing the tender fee amounting to Rs.200 (Non Refundable) in the shape of pay order in favor of Accounts Officer, UCG Thar Project, Islamkot.

- 2) The tenders will be received back upto 11.04-2013 at 11:00 and will be opened on the same day at 1500hrs in the presence of Purchase Committee and the bidders or their authorized representatives who wish to be present.
- 3) Bid Security amounting to 2% of Bid Price should be submitted along with the Bid in shape of Pay Order in favor of Accounts Officer, UCG Thar Project, issued by any scheduled Bank of Pakistan.
- 4) The bid security will be forfeited to the Government, if the bidder withdraws his bid after opening and before the expiry of the bid validity period or fails to sign the contract if the bid is accepted.
- 5) 10% service performance will be held till the completion of job meanwhile 2% bid Price will be released.
- 6) Amount of the tender is below Rs. One Million.
- 7) Conditional tender and tender without bid security shall not be considered.
- 8) Delivery time will be 10 days after the issuance of supply order.
- 9) GST/Income Tax Certificates, as the case may be, must be submitted with the tender documents.
- 10) The procuring agency may reject all or any bid at any time prior to the acceptance of a bid or proposal, subject to the relevant provisions of SPP Rules 2010.
- 11) Tender envelope should bear the tender No. UCG/Tender/Mech-72/2013 and the wording "Tender for H.P & Feed Pumps".

Assistant Manager (Admin)
UCG Thar Project Site,
C/O Manager,
National Bank of Pakistan
Islamkot.
Ph: 0232-923036
0232-923037