

Paras

DMD (TS) KW&SB  
Dairy No. 464/N  
Dated. 5/4/17

( 2 )

Dy: No. 02  
Date: 5-4-17  
Reference

SUBJECT: REPAIR & MAINTENANCE OF 24" DIA VERTICAL SLUICE VALVE AT COD FILTER PLANT AND INTERNAL LEAKAGES ON 54" DIA PRCC WATER TRUNK MAIN PIPE AT COD FILTER PLANT.

It is submitted that 02 Nos. 24" dia vertical sluice valves have become very deteriorated – out of order / not functioning properly which is using for the purpose of dropping at sump of Kidney Hill Pump House and feeding to Reservoir through Rising Main and adjoining areas. Due to this worst condition of the 24" dia vertical sluice valve, creating problems in operation and it is also observed that leakages has also appeared on 54" dia PRCC Trunk Main Line which is feeding to Kidney Hill Reservoir, hence this work is very important / essential as per water supply point of view.

The concerned Sub Engineer & Assistant Executive Engineer prepared an estimate amounting to Rs. 4,64,801/- and Director (Design) has been checked for Rs.4,64,801/- as per Para 5/N to 9/N.

Sufficient fund is available under H/A No.6083-23 of the printed budget estimate 2016-17 to meet the expenditure,

In view of the above, it is therefore, requested that administrative approval for calling tender through website as per SPPR-2010 ammended 2013 may please be obtained from M.D., KW&SB.

Submitted please.

Executive Engineer,  
Karachi Divn (Civil-I),  
KW&SB.

The S.E(BT&D), KW&SB.

For approval of Para 14/N please. 5/4/17

DMD-TS

Recommended & Forwarded for obtaining administrative approval by the MD, KW&SB as requested by the SE (BT&D) vide para 16/u

DMD (T.S.)

MD, KW&SB

Approval accorded as proposed by DMD (T.S.) Subject to comply with SPRA Rules & other formalities.

DMD (T.S.)

MD-KW&SB

M.D. KW&SB  
Dairy No. 1158/N  
Date: 26/4/17  
Time

T.S.  
b  
DMD