

SUBJECT: EMERGENT REPAIR OF LEAKAGES ON 36" DIA M.S. PIPE INTERCONNECTION OF K-III RISING MAIN AT N.E.K. & 48" DIA / LEAKAGES ON PRCC PIPE.

DMD (T.S.)
Daily No. 698/12
Dated 2-5-2017

It is submitted that a heavy leakage has been appeared on 36" dia interconnection of K-III Twin Rising Main which is feeding to Greater Karachi Conduit for the improvement of main supply of Karachi City, resulting this the water level is continuously decreasing / going down due to rusted / corroded M.S. Pipe. Hence repair of leakage of M.S. Pipe is very essential.

The concerned Sub Engineer & Assistant Executive Engineer prepared an estimate amounting to Rs. 9,61,866/- and Director (Design) has been checked for Rs. 8,63,156/- as per Para 5/N to 10/N.

Sufficient fund is available under H/A No.6083-29 of the printed budget estimate 2016-17 to meet the expenditure,

In view of the above, it is therefore, requested that administrative approval for calling tender through website as per SPPR-2010 ammended 2013 may please be obtained from M.D., KWSB.

Submitted please.

Executive Engineer,
Karachi Divn. (Civil-I),
KW&SB

The S.E(BT&D), KWSB.

Recommended for approval
vide para 17/N at P-2 as
initiated by TEN concerned
please

DMD (T.S.)

21/3/2017
SE(BT&D)

Recommended & Forwarded for obtaining
administrative approval by the MD KWSB
as requested by the SE(BT) vide para 19/N

MD KWSB
DMD (T.S.)

MD KWSB

Approved & recommended by DMD (T.S.) and
proceed further in accordance to SPPRA Rules & other franchises