

The connector shall be of suitable rating having porcelain body, sunk-in screw terminals and terminal strips. The connector shall be wrapped with PVC insulation tape after its installation. A minimum of 150 mm extra length of cable/wire shall be provided at each termination to facilitate repairs in future.

1.8 INSULATION RESISTANCE TESTS

Insulation resistance tests shall be made on all electrical equipment by using a megger tester of 500V for circuits upto 250 Volts and 1000V for circuits upto 500 volts.

The insulation resistance values of cables, transformers and switchgear etc., shall be as per B.S.S. and Pakistan Electricity Rules.

Before making connections at the ends of each cable run, the insulation resistance measurement test of each cable shall be made. If insulation resistance test readings are found to be less than the specified minimum, the cable shall be replaced and the new cable installed and tested.

All switchgears shall be given an insulation resistance measurement test after installation, before any wiring is connected. Insulation tests shall be made between open contacts of circuit breakers, switches and between each phase and earth.

If the insulation resistance of the circuit under test is less than the specified value, the cause of the low reading shall be determined and removed. Corrective measures shall include dry-out procedure by means of heaters if equipment is found to contain moisture. After all tests have been made, the equipment shall be reconnected as required.

1.9 CONTINUITY TEST

Continuity test on all the sub and main circuits should be performed for phase, neutral & earth wires.

END OF SECTION