

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions, apply to this Section.

1.2 SUMMARY

- A. This Section includes requirements for 600 volt cables & associated accessories.

1.3 DEFINITIONS

- A. Not used.

1.4 PERFORMANCE REQUIREMENTS

- A. Not used.

1.5 SUBMITTALS

- A. None required.

1.6 DESCRIPTION

- A. Provide 600 / 1000 volt cable in accordance with the Contract Documents.

1.7 WORK INCLUDED

- A. Supply of 600 / 1000 volt Cable.

1.8 QUALITY ASSURANCE

- A. Except as modified by applicable codes and by the Contract Documents, comply with the latest applicable provisions and latest recommendations of the following:
1. General: British standard (BS) approvals service for Electric Cables (BASEC).
 2. Cross-Linked Polyethylene (XLPE) Insulated Wire and Cables:
 - a. BS6633: Cross-Linked Thermosetting-Polyethylene-Insulated Wire and Cable for the Transmission and Distribution of Electrical Energy.
 - b. BS6633: Rubber-Insulated Wires and Cables.
 - c. BS6633: Service-Entrance Cable.
 3. Annealed Copper Wire for Conductors:
 - a. BS6633: Soft or Annealed Copper Wire.