


PLAN  
STA. 8+500 TO 9+000



PROFILE  
STA. 8+500 TO 9+000

**NOTE:-**

1. ALL DIMENSIONS ARE IN METERS UNLESS OTHERWISE STATED.
2. MIN COVER SHALL BE OF 2m UNLESS OTHERWISE PIPE SHALL BE ENCASED.
3. FOR PIPE TRENCH REFER DWG.NO.EA-942-65M-PIII-U-W400
4. FOR THRUST BLOCK REFER DWG.NO.EA-942-65M-PIII-U-W401
5. FOR BUTTERFLY VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W402
6. FOR AIR RELEASE VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W403
7. FOR WASHOUT VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W404
8. FOR DETAIL TYPICAL PIPE CROSSING REFER DWG.NO.EA-942-65M-PIII-U-W405
9. FOR RAILWAY CROSSING REFER DWG.NO.EA-942-65M-PIII-U-W406
10. FOR FOREBAY CHAMBER PLAN REFER DWG.NO.EA-942-65M-PIII-U-W407
11. FOR FOREBAY CHAMBER SECTION REFER DWG.NO.EA-942-65M-PIII-U-W408
12. 1800mm INNER DIAMETER TO BE PROVIDED WITH 12MM THICKNESS.

**LEGEND FOR PLAN:-**

PROPOSED PIPE LINE

AIR RELEASE VALVE

WASHOUT VALVE

BUTTERFLY VALVE

**EXISTING SERVICES:**

WATER LINE

ICI WATER

PORT QASIM WATER

PAKISTAN STEEL WATER

GREATER KARACHI

**KARACHI WATER II**

**KARACHI WATER III**

**ELECTRIC LINE**

**SUI SOUTHERN GAS**

**LEGEND FOR PROFILE:-**

NATURAL GROUND

PROPOSED PIPE

AIR RELEASE VALVE

WASHOUT VALVE

BUTTERFLY VALVE

CLIENT:-

**KARACHI WATER & SEWERAGE BOARD**

CONSULTANT:-

**EA Consulting ( Pvt. ) Limited**

IN ASSOCIATION WITH:-

**Jers Engineering Consultant**

PROJECT:-

**ADDITIONAL 65 MGD WATER SUPPLY SCHEME FROM HALEJI TO PIPRI, KARACHI.**

DRAWN: SAIF

DESIGNED: SIDRA

CHECKED: MUNAWAR

APPROVED: ALI ASGHAR

TITLE: PUMPING MAIN MS PIPE Ø 1800mm PLAN & PROFILE (STA = 8+500 TO 9+000)

Scale / Sheet: H=1:1000 ( A1 ) V=1:100

Drawing No.: EA-942-65M-PIII-U-PP14

PACKAGE # 03

0	APR,18	TENDER DRAWINGS	S.A.S	M.Z	A.A
ED.NO	DATE	DESCRIPTION	BY	CKD	APR