


PLAN
STA. 8+100 TO 8+500



PROFILE
STA. 8+100 TO 8+500

NOTE:-

- ALL DIMENSIONS ARE IN METERS UNLESS OTHERWISE STATED.
- MIN COVER SHALL BE OF 2m UNLESS OTHERWISE PIPE SHALL BE ENCASED.
- FOR PIPE TRENCH REFER DWG.NO.EA-942-65M-PIII-U-W400
- FOR THRUST BLOCK REFER DWG.NO.EA-942-65M-PIII-U-W401
- FOR BUTTERFLY VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W402
- FOR AIR RELEASE VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W403
- FOR WASHOUT VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W404
- FOR DETAIL TYPICAL PIPE CROSSING REFER DWG.NO.EA-942-65M-PIII-U-W405
- FOR RAILWAY CROSSING REFER DWG.NO.EA-942-65M-PIII-U-W406
- FOR FOREBAY CHAMBER PLAN REFER DWG.NO.EA-942-65M-PIII-U-W407
- FOR FOREBAY CHAMBER SECTION REFER DWG.NO.EA-942-65M-PIII-U-W408
- 1800mm INNER DIAMETER TO BE PROVIDED WITH 12MM THICKNESS.

LEGEND FOR PLAN:-

PROPOSED PIPE LINE

AIR RELEASE VALVE

WASHOUT VALVE

BUTTERFLY VALVE

EXISTING SERVICES:

WATER LINE

ICI WATER

PORT QASIM WATER

PAKISTAN STEEL WATER

GREATER KARACHI

LEGEND FOR PROFILE:-

NATURAL GROUND

PROPOSED PIPE

AIR RELEASE VALVE

WASHOUT VALVE

BUTTERFLY VALVE

KARACHI WATER II

KARACHI WATER III

ELECTRIC LINE

SUI SOUTHERN GAS

0 APR,18

TENDER DRAWINGS

S.A.S

M.Z

A.A

ED.NO

DATE

DESCRIPTION

BY

CKD

APR

CLIENT:-

KARACHI WATER & SEWERAGE BOARD

CONSULTANT:-

EA Consulting (Pvt.) Limited

IN ASSOCIATION WITH:-

Jers Engineering Consultant

PROJECT:-

ADDITIONAL 65 MGD WATER SUPPLY SCHEME FROM HALEJI TO PIPRI, KARACHI.

DRAWN

SAIF

DESIGNED

SIDRA

CHECKED

MUNAWAR

APPROVED

ALI ASGHAR

TITLE

PUMPING MAIN MS PIPE Ø 1800mm

PLAN & PROFILE

(STA = 8+100 TO 8+500)

Scale / Sheet

H=1:1000

V=1:100

(A1)

Drawing No.

EA-942-65M-PIII-U-PP13

PACKAGE # 03