


PLAN
STA. 2+700 TO 3+000



PROFILE
STA. 2+700 TO 3+000

NOTE:-

- ALL DIMENSIONS ARE IN METERS UNLESS OTHERWISE STATED.
- MIN COVER SHALL BE OF 2m UNLESS OTHERWISE PIPE SHALL BE ENCASED.
- FOR PIPE TRENCH REFER DWG.NO.EA-942-65M-PIII-U-W400
- FOR THRUST BLOCK REFER DWG.NO.EA-942-65M-PIII-U-W401
- FOR BUTTERFLY VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W402
- FOR AIR RELEASE VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W403
- FOR WASHOUT VALVE CHAMBER REFER DWG.NO.EA-942-65M-PIII-U-W404
- FOR DETAIL TYPICAL PIPE CROSSING REFER DWG.NO.EA-942-65M-PIII-U-W405
- FOR RAILWAY CROSSING REFER DWG.NO.EA-942-65M-PIII-U-W406
- FOR FOREBAY CHAMBER PLAN REFER DWG.NO.EA-942-65M-PIII-U-W407
- FOR FOREBAY CHAMBER SECTION REFER DWG.NO.EA-942-65M-PIII-U-W408
- 12. 1800mm INNER DIAMETER TO BE PROVIDED WITH 12MM THICKNESS.**

LEGEND FOR PLAN:-

PROPOSED PIPE LINE — W —

AIR RELEASE VALVE (A)

WASHOUT VALVE (B)

BUTTERFLY VALVE (C)

EXISTING SERVICES:

WATER LINE — WL — WL —

ICI WATER — ICI — ICI —

PORT QASIM WATER — POL — POL —

PAKISTAN STEEL WATER — PSL — PSL —

GREATER KARACHI — GK — GK —

KARACHI WATER II — KII — KII —

KARACHI WATER III — KIII — KIII —

ELECTRIC LINE — V — V —

SUI SOUTHERN GAS — GAS — GAS —

LEGEND FOR PROFILE:-

NATURAL GROUND — — —

PROPOSED PIPE — — —

AIR RELEASE VALVE (A)

WASHOUT VALVE (B)

BUTTERFLY VALVE (C)

0	APR,18	TENDER DRAWINGS	S.A.S	M.Z	A.A
ED.NO	DATE	DESCRIPTION	BY	CKD	APR

CLIENT:-

KARACHI WATER & SEWERAGE BOARD

CONSULTANT:-

EA Consulting (Pvt.) Limited

IN ASSOCIATION WITH:-

Jers Engineering Consultant

PROJECT:-

ADDITIONAL 65 MGD WATER SUPPLY SCHEME FROM HALEJI TO PIPRI, KARACHI.

DRAWN	SAIF	TITLE PUMPING MAIN MS PIPE Ø 1800mm PLAN & PROFILE (STA = 2+700 TO 3+000)
DESIGNED	SIDRA	
CHECKED	MUNAWAR	Scale / Sheet H=1:1000 V=1:100 (A1)
APPROVED	ALI ASGHAR	

PACKAGE # 03

Drawing No.
EA-942-65M-PIII-U-PP05